



# APPLICATION FOR APPEAL

**Saint Paul City Clerk**

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

RECEIVED

NOV 24 2010

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

**YOUR HEARING Date and Time:**

Tuesday, Dec. 14, 2010

Time 1:30 P.M.

Location of Hearing:

Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 334 S Saratoga St. City: S. Paul State: MO Zip: 55105

Appellant/Applicant: Custom Remodelers Inc. Dan Parker Email: Judy.h@customremodelersinc.com

Phone Numbers: Business (651) 784-2646 Residence (651) 699-0834 Cell \_\_\_\_\_

Signature: [Handwritten Signature] Date: 11/24/2010

Name of Owner (if other than Appellant): Lenny / Rita Laier

Address (if not Appellant's): \_\_\_\_\_

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

## What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

Permit # 201030643  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

Brian Helle  
Jake S.

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: July 20, 2010

APPEAL PROPERTY ADDRESS: 334 SARATOGA ST S *Job # 29593-5*

APPLICANT NAME: CUSTOM REMODELERS INC

PHONE NUMBER: 651-266-9025

PERMIT NUMBER: 10 310643

TYPE OF WINDOW Double hung

NUMBER OF WINDOWS 3 - one in each bedroom.

Total Glazed Area	7'-6" sq. Ft.	Difference from Required Area	1'-9"
Width of Opening	23"	Difference from Required Opening	+3"
Height of Opening	22"	Difference from Required Opening	-2"
Height of Opening to Finished Floor	26"	Difference from Maximum Height	18"

COMMENTS: The windows do not meet St. Paul's egress code.

Reviewed by: Michael A. Palm

*Leiar*