

✓ Scanned

RECEIVED

JAN 10 2012

CITY CLERK

Saint Paul - Ramsey County Department of Public Health
Environmental Health Section
2785 White Bear Avenue North Suite 350
Maplewood, MN 55109-1320
FAX: (651) 266-1177

Date: 1-10-12



P. 1
No. 9426
St Paul-Ramsey Co. Public Health
3:51PM
Jan. 10. 2012

FACSIMILE TRANSMISSION
Cover Sheet and Transmittal Form

To FAX#: 6-8574
mtg date 1-17-12 @ 1:30

To:	<u>Mai Yang, Paralegal</u>
Location:	<u>Legislative Hearing Office City of St. Paul</u>
Sender:	<u>Daniel Schmidt / Jim Yannarelli St. Paul - Ramsey Cty. Dept. of Public Health</u>

This transmission consists of 3 pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1143 (DANIEL SCHMIDT)

message:

Request for Egress Window Non-Compliance Determination

Attachments: Egress Window Non-Compliance Determination Form

CONFIDENTIALITY NOTICE

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

No. 9426 P. 2

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 1-10-12

APPEAL PROPERTY ADDRESS: 731 Hoyt Ave

APPLICANT NAME: PUBLIC HEALTH (DANIEL SCHMIDT) PHONE NUMBER: 651-266-1143

PERMIT NUMBER: _____

TYPE OF WINDOW: DH

NUMBER OF WINDOWS: 1

TOTAL GLAZED AREA: 11 sq ft DIFFERENCE FROM REQUIRED AREA: COMPLIES

WIDTH OF OPENING: 31.2" DIFFERENCE FROM REQUIRED OPENING: COMPLIES

HEIGHT OF OPENING: 19.93" DIFFERENCE FROM REQUIRED OPENING: 4.17"

HEIGHT OF OPENING
TO FINISHED FLOOR: 248" DIFFERENCE FROM MAXIMUM HEIGHT: COMPLIES

RECOMMENDATION (IF APPLICABLE): _____

FROM: _____

Jan. 10. 2012 3:52PM

Select a Model		Min. W: 11	Max. W: 52
		Min. H: 20	Max. H: 84
		Max. U/I: 132	
(Model 0201) Excalibur Double Hung			
Top Sash Width	32.3750	Exact Size	
Top Sash Height	25.1250	Width: 35.625	35.625
Bottom Sash Width	33.3750	Height: 53.375	53.375
Bottom Sash Height	26.4250		
Top Glass Width	30.6875	Extrusion: Select Extrusion << For Arch-Top Models Only	
Top Glass Height	23.4375	Opening: Exact Size	
Bottom Glass Width	31.6875	Type: Standard	
Bottom Glass Height	24.4375	Screen: Full	
Screen Width	34.9375	Glass: Double Strength (3 pan)	
Screen Height	40.8000	<input type="checkbox"/> AC Sash Calculator	
Top Sash Weight (Plus 5 lb)	24 lb		
Top Balance Size (C.F)	65YH		
Top Balance Size (Spiral)	21-9B		
Bottom Sash Weight	21 lb		
Bottom Balance Size (C.F)	56BU		
Bottom Balance Size (Spiral)	25-8R		
Egress Opening Width	31.2190		
Egress Opening Height	19.9375		
Egress Opening Area (sq.ft.)	4.3226		

31.9 x 50.5 = 1611 ÷ 11 sq ft

TOTAL GLAZED AREA