



APPLICATION FOR APPEAL

RECEIVED

NOV 10 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 11-23-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Esther Dahl 11-10-11

Address Being Appealed:

Number & Street: 905 White Bear Ave City: _____ State: _____ Zip: _____

Appellant/Applicant: Window World-Esther Dahl Email estherd@windowworldmn.com

Phone Numbers: Business 651-770-9315 Residence _____ Cell _____

Signature: *Esther Dahl* Date: 11/7/11

Name of Owner (if other than Appellant): T & M Properties

Address (if not Appellant's): same as site

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O _____
- Summary/Vehicle Abatement _____
- Fire C of O Deficiency List _____
- Fire C of O: Only Egress Windows _____
- Code Enforcement Correction Notice _____
- Vacant Building Registration _____
- Other Asking for Variance on windows, we are OK on square
- Other footage,
- Other _____



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 27, 2011

APPEAL PROPERTY ADDRESS: 905 WHITE BEAR AVE N

APPLICANT NAME: WINDOW WORLD

PHONE NUMBER: 651-770-9315

PERMIT NUMBER: 11 132422

TYPE OF WINDOW Casement

NUMBER OF WINDOWS 5- Five

Total Glazed Area Minimum 5 Square Feet	OK	Difference from Required Area	OK
Width of Opening Minimum 20 Inches	OK	Difference from Required Opening	OK
Height of Opening Minimum 24 Inches	OK	Difference from Required Opening	OK
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	54"	Difference from Maximum Height	+6"

COMMENTS:

Reviewed by: David Nelson