

Date: July 24, 2020
File #: 20 - 050225
Folder Name: 905 MARYLAND AVE E
PIN: 212922330149



Since storage is not flush with the wall, it needs 2' clearance from ceiling.

Note, storage which is flush with the wall can go to the ceiling. So there is no code concern with the white shelving unit.

Note, removing this suspended board is not in the order. However, in reviewing this photo, the Commercial Fire Inspection Supervisor, James Perucca, thought that its removal would allow you to: 1) add storage upward on the wall with the white shelving unit (and perhaps the opposite wall which is not in this photo); and 2) create a center isle for storage which would have adequate distance from the ceiling.

Date: July 24, 2020
File #: 20 - 050225
Folder Name: 905 MARYLAND AVE E
PIN: 212922330149



Storage is within 2 feet of the ceiling and must be removed.