



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street., Suite 220
Saint Paul, MN 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-1919
Web: www.stpaul.gov/dsi

355

January 28, 2013

12-111992

Siu Lui Fung
616 Case Ave
Saint Paul MN 55130-4046

Siu Lui Fung
528 Rice Street
Saint Paul MN 55103-0652

EMC Mortgage Corp
4720 Independence St
Wheat Ride CO 80033

Siu Lui Fung
1271 22nd Avenue
San Francisco CA 94122

Order to Abate Nuisance Building(s)

Dear Sir or Madam:

The Vacant/Nuisance Buildings Unit, Department of the Department of Safety and Inspections, Division of Code Enforcement, hereby declares the premises located at:

616 CASE AVE

With the following Historic Preservation information: NONE
and legally described as follows, to wit:

Chas Weides Sub B25 26 Arlingt Lot 43 Blk 25

to comprise a nuisance condition in violation of the Saint Paul Legislative Code, Chapter 45.02, and subject to demolition under authority of Chapter 45.11.

On November 30, 2012 a Building Deficiency Inspection Report was compiled and the following conditions were observed.

This list of deficiencies is not necessarily all the deficiencies present at this time. This building(s) is subject to the restrictions of Saint Paul Ordinance Chapter 33.03 and shall not again be used for occupancy until such time as a Certificate of Compliance or a Certificate of Occupancy has been issued. All repairs must be in accordance with appropriate codes. Changes or additions to the electrical system, mechanical system, or the plumbing system may necessitate updating or upgrading the systems involved.

This is a one and one-half story, wood frame, single-family dwelling with a wood frame shed.

The following is excerpted from the January 7, 2013 Code Compliance Inspection Report:

BUILDING

- Remove mold, mildew and moldy or water damaged materials.
- Permanently secure top and bottom of support posts in an approved manner.
- Install handrails (34 inches - 38 inches above each nosing) and guardrails (36 inch minimum) at all stairways, and return hand rail ends into a newel post or wall per attachment.
- Repair or Replace any deteriorated window sash, broken glass, sash holders, re-putty, etc as necessary.
- Provide complete storms and screens, in good repair for all door and window openings.
- Provide functional hardware at all doors and windows
- Exit doors shall be capable of being opened from the inside, easily and without the use of a key. Remove all surface bolts.
- Repair or replace damaged doors and frames as necessary, including storm doors.
- Weather seal exterior doors, threshold and weather-stripping.
- Repair walls, ceiling and floors throughout, as necessary.
- Prepare and paint interior and exterior as necessary. Observe necessary abatement procedures (EPA, MPCA and St. Paul Legislative Code, Chapter 34 for additional information) if lead base paint is present.
- Any framing members that required repair or do not meet code (where wall and ceiling covering is removed, members that are over-spanned, over-spaced, not being carried properly, door and window openings that are not adequately supported, etc.) are to be reconstructed in an approved manner.
- Charred building components shall be scraped or sandblasted completely clean and water-damaged components replaced. A determination of necessary fire damage corrective measures shall be made by this department or by a registered structural engineer as to replacement, repairs, etc. All smoke damaged and charred members shall be cleaned, sealed and deodorized.
- Provide fire block construction as necessary and seal chases in basement ceiling.
- Where wall and ceiling covering is removed install full thickness or code-specified insulation.
- Air-seal and insulate attic/access door.
- Install Smoke Detectors/Carbon Monoxide Detectors per MN Conservation Code and the MN Dept. of Labor and Industry: Install per code where feasible.
- Provide major clean-up of premises.
- Repair siding, soffit, fascia, trim, etc. as necessary.
- Provide proper drainage around house to direct water away from foundation of house.
- Provide proper drainage around house to direct water away from foundation of garage.
- Install downspouts and a complete gutter system.
- Install rain leaders to direct drainage away from foundation.
- Install address numbers visible from street and on the alley side of garage.
- Provide durable, dustless parking surface as specified in the zoning code.
- Remove trees which are against foundation of home and garage.
- Grade must drain away from foundation of dwelling. Maintain 6 inch clearance between wood and soil.

- Replace all fire damaged siding, windows, trim and framing on west side of house.
- Replace or re-level basement stairs.
- Remove ceiling covering from 1st. and 2nd floor.
- Remove all wall covering in 2nd floor west bedroom and hall stair area.
- Replace all fire damaged roof framing, roof boards and shingles.
- Provide major repair of storage shed or remove.
- A building permit is required to correct the above deficiencies.

ELECTRICAL

- Close openings in junction boxes with knockout seals and/or junction box covers in basement and attic.
- Repair or Replace all broken, missing or loose light fixtures, switches and outlets, covers and plates
- Check all outlets for proper polarity and verify ground on 3-prong outlets
- Install hard-wired, battery backup smoke detector and other smoke detectors as required by the IRC. Also, Install carbon monoxide detector(s) within 10 feet of all bedrooms
- Remove and or/ re-wire all illegal, improper or hazardous wiring in basement, garage and attic.
- Replace all painted-over receptacles.
- Add receptacle in first floor bedroom per SPLC 34.14(2)b.
- Repair/rewire all fire damaged areas to 2011 NEC.
- Based on repair list purchase permit for 15 circuits.
- All added receptacles must be grounded, tamper-resistant and be on an Arc-Fault Circuit Interrupter-protected circuit.
- Any open walls or walls that are opened as part of this project must be wired to the standards of the current NEC.
- All electrical work must be done by a Minnesota-licensed electrical contractor under an electrical permit.

PLUMBING

- Basement - Water Heater - not fired or in service (MPC 2180)
- Basement - Water Meter - support meter properly (MPC 2280)
- Basement - Water Piping - add appropriate hangers (MPC 1430 Subp. 4)
- Basement - Water Piping - provide water piping to all fixtures and appliances (MPC 1700)
- Basement - Water Piping - repair or replace all corroded, broken or leaking piping (MPC 4715.1720)
- Basement - Gas Piping - dryer gas shutoff; connector or piping incorrect (MFGC 411)
- Basement - Gas Piping - retest all gas piping for Xcel meter unlock (MFGC 406.1)
- Basement - Gas Piping - run dryer vent to code (MFGC 614.1 - 614.7)
- Basement - Soil and Waste Piping - unplugged or open piping; back pitched piping (MPC 1000)
- First Floor - Toilet Facilities - reset the toilet on a firm base (MPC 0870)
- First Floor - Tub and Shower - waste incorrect (MPC 2300)
- Second Floor - Toilet Facilities - reset the toilet on a firm base (MPC 0870)

- Exterior - Verify main plumbing stack is installed to code; with the proper vent through the roof.
- All the above corrections to waste, vent, water, and gas piping shall be per the Minnesota Plumbing Code Chapter 4715 & Chapter 326, the Minnesota Mechanical Code, the Minnesota Fuel Gas Code, and the Saint Paul Regional Water Code. All plumbing must be done by a plumbing contractor licensed in the State of Minnesota and the City of St. Paul under an approved permit.

HEATING

- Clean and Orsat test furnace burner. Check all controls for proper operation. Check furnace heat exchanger for leak; provide documentation from a licensed contractor that the heating unit is safe
- Vent clothes dryer to code
- Provide adequate combustion air and support duct to code
- Provide support for gas lines to code
- Plug, cap and/or remove all disconnected gas lines
- All supply and return ducts for warm air heating system must be clean before final approval for occupancy. Provide access for inspection of inside of ducts or provide documentation from a licensed duct-cleaning contractor that the duct system has been cleaned.
- Repair and/or replace heating registers as necessary
- Provide heat in every habitable room and bathrooms
- Conduct witnessed pressure test on gas piping to attic.
- Secure condensate drain line from A/C evaporator in basement.
- Unable to gain entry to attic during inspection. If there is any nonconforming heating equipment in there, remove it and all connecting piping, venting, ductwork and permanently seal and plug all openings or install equipment to code. All ducts in unconditioned spaces must be sealed and insulated to an R-8 rating.
- Mechanical gas permit is required for the above work.

As owner, agent or responsible party, you are hereby notified that if these deficiencies and the resulting nuisance condition is not corrected by **February 27, 2013** the Department of Safety and Inspections, Division of Code Enforcement, will begin a substantial abatement process to demolish and remove the building(s). The costs of this action, including administrative costs and demolition costs will be assessed against the property taxes as a special assessment in accordance with law.

As first remedial action, a Code Compliance Inspection Report must be obtained from the Building Inspection and Design Section, 375 Jackson Street, Suite 220, (651) 266-8989. This inspection will identify specific defects, necessary repairs and legal requirements to correct this nuisance condition. You may also be required to post a five thousand dollar (\$5,000.00) performance bond with the Department of Safety and Inspections before any permits are issued, except for a demolition permit. Call the Department of Safety and Inspections for more information at 651-266-8989.

If this building is located in a historic district or site (noted on page 1, above, just below the property address) then you must contact Heritage Preservation (HPC) staff to discuss your proposal for the repairs required by this order and compliance with preservation guidelines.

Copies of the guidelines and design review application and forms are available from the Department of Safety and Inspections web site (see letterhead) and from the HPC staff. No permits will be issued without HPC review and approval. HPC staff also can be reached by calling 651-266-9078.

As an owner or responsible party, you are required by law to provide full and complete disclosure of this "Order to Abate" to all interested parties, all present or subsequent renters and any subsequent owners. The property shall not be sold, transferred or conveyed in any manner until the Nuisance Conditions have been abated and the Certificate of Code Compliance or Certificate of Occupancy has been issued.

The Enforcement Officer is required by law to post a placard on this property which declares it to be a "nuisance condition", subject to demolition and removal by the City. This placard shall not be removed without the written authority of the Department of Safety and Inspections, Division of Code Enforcement. The department is further required to file a copy of this "Order to Abate" with the City Clerk's Office.

If corrective action is not taken within the time specified in this order, the Enforcement Officer will notify the City Council that abatement action is necessary. The City Clerk will then schedule dates for Public Hearings before the City Council at which time testimony will be heard from interested parties. After this hearing the City Council will adopt a resolution stating what action if any, it deems appropriate.

If the resolution calls for abatement action the Council may either order the City to take the abatement action or fix a time within which this nuisance must be abated in accordance with the provisions of Chapter 33 of the Saint Paul Legislative Code and provide that if corrective action is not taken within the specified time, the City shall abate this nuisance. The costs of this action, including administrative costs will be assessed against the property as a special assessment in accordance with law.

If you have any questions or request additional information please contact **Tom Friel** between the hours of 8:00 and 9:30 a.m. at **651-266-1906**, or you may leave a voice mail message.

Sincerely,

Tom Friel
Vacant Buildings Enforcement Inspector

cc: Legistar Approval list and City Council