



**CITY OF SAINT PAUL**  
OFFICE OF THE CITY COUNCIL  
310 CITY HALL  
15 WEST KELLOGG BOULEVARD  
SAINT PAUL, MN 55102-1615  
EMAIL: [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us)  
PHONE: (651) 266-8560 FAX: (651) 266-8574

January 18, 2011

Window World  
Esther Dahl  
[esterhd@windowworldmn.com](mailto:esterhd@windowworldmn.com)  
2211 11th Ave E - #130  
North St Paul MN 55109

Re: Appeal for property at 1401 Arundel Street (Roger Strohbeen)  
File ID: ALH 11-112

Dear Ms. Dahl:

This is to confirm that on January 12, 2011, Marcia Moermond, Legislative Hearing Officer reviewed the above-referenced appeal and recommended granting a 4-inch variance on the openable height of two double hung replacement egress bedroom windows which measured both at 20 inches high by 28.5 inches wide.

If you have any questions, you may contact me at 651-266-8563.

Sincerely,  
/s/

Mai Vang  
Legislative Hearing Coordinator

cc: Fire Supervisors (email)  
Pat Fish (email)  
Jim Bloom (email)  
Stephen Ubl (email)  
File

