



**CITY OF SAINT PAUL**  
OFFICE OF THE CITY COUNCIL  
310 CITY HALL  
15 WEST KELLOGG BOULEVARD  
SAINT PAUL, MN 55102-1615  
EMAIL: [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us)  
PHONE: (651) 266-8560 FAX: (651) 266-8574

February 25, 2011

Thomas Smith  
66 – 9<sup>th</sup> St E, Unit 2506  
St Paul MN 55101

RE: Appeal for property at 888 Clark Street  
File ID: ALH 11-277

Dear Mr. Smith:

This is to confirm that the Legislative Hearing Officer reviewed the above-referenced appeal and recommended granting a 4-inch variance on the openable height of the egress window in bedroom one, Unit 2; and granting a 2.5-inch variance on the openable height of the egress window in bedroom two. Your hearing for March 1, 2011 at 1:30 p.m. has been canceled.

If you have further questions, I can be reached at 651-266-8563.

Sincerely,

Mai Vang  
Legislative Hearing Coordinator

c: Fire Supervisors (email)  
Pat Fish (email)

