

Vang, Mai (CI-StPaul)

From: Shaff, Leanna (CI-StPaul)
Sent: Monday, August 12, 2019 12:03 PM
To: Moermond, Marcia (CI-StPaul); Vang, Mai (CI-StPaul)
Subject: 1091 Maryland Ave E inspection today
Attachments: 1091.3.pdf; 1091.1.pdf; 1091.2.pdf

Here are my notes from the inspection today:

8/12/19 Tenant appealed vacate notice. Hearing on 8/6/19. LHO requiring safety inspection for continued occupancy. Inspected this morning accompanied by Inspector Vue. No carbon monoxide alarms in house. Smells like litter box and mildew throughout the home. Excessive amount of flies in various stages of growth. Excessive mildew in basement. Excessive amount of combustible materials. Found extension cords being used throughout the home, and additional electrical issues, i.e.: loose switches, nonfunctioning lights in the basement. There is cat feces/vomit dried to the floor. LS



Leanna Shaff, CBO, CFI

Fire Safety Inspector III

Department of Safety and Inspections

375 Jackson Street, Suite 220

Saint Paul, MN 55101

P: 651-266-8980

F: 651-266-8951

leanna.shaff@ci.stpaul.mn.us

The Most Livable
City in America



Making Saint Paul the Most Livable City in America

“DSI’s Mission: To preserve and improve the quality of life in Saint Paul by protecting and promoting public health and safety for all.”