


Scanned



Saint Paul - Ramsey County Department of Public Health
Environmental Health Section
2785 White Bear Avenue North Suite 350
Maplewood, MN 55109-1320
FAX: (651) 266-1177

Date: 12-15-11

Fax Notice

To FAX#: 6-8574

1-3-12 11:30

No. 9269

Public Health
St Paul - Ramsey Co.

Dec. 15, 2011
3:43PM

FACSIMILE TRANSMISSION
Cover Sheet and Transmittal Form

To:	Mai Vang, Paralegal
Location:	Legislative Hearing Office City of St. Paul
Sender:	Daniel Schmidt / Jim Yannarelli St. Paul - Ramsey Cty. Dept. of Public Health

This transmission consists of 3 pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1143 (DANIEL SCHMIDT)

Message:

Request for Egress Window Non-Compliance Determination

Attachments: Egress Window Non-Compliance Determination Form

CONFIDENTIALITY NOTICE

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

No. 9269 P. 2.

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 12-15-11

APPEAL PROPERTY ADDRESS: 900 CASE

APPLICANT NAME: PUBLIC HEALTH (DANIEL SCHMIDT) PHONE NUMBER: 651-266-1143

PERMIT NUMBER: _____

TYPE OF WINDOW: DH

NUMBER OF WINDOWS: 1

TOTAL GLAZED AREA: 8.3 sq ft DIFFERENCE FROM REQUIRED AREA: COMPLIES

WIDTH OF OPENING: 24" DIFFERENCE FROM REQUIRED OPENING: COMPLIES

HEIGHT OF OPENING: 20" DIFFERENCE FROM REQUIRED OPENING: 4"

HEIGHT OF OPENING
TO FINISHED FLOOR: < 48" DIFFERENCE FROM MAXIMUM HEIGHT: COMPLIES

RECOMMENDATION (IF APPLICABLE): _____

FROM: _____

Dec. 15. 2011 3:43PM

Select a Model

(Model 0201) ▼
Excalibur Double Hung

Top Sash Width	25.2500
Top Sash Height	25.1875
Bottom Sash Width	26.2500
Bottom Sash Height	25.1875
Top Glass Width	23.5625
Top Glass Height	23.5000
Bottom Glass Width	24.5625
Bottom Glass Height	24.5000
Screen Width	24.8125
Screen Height	50.6250
Top Sash Weight (Plus 5 lb)	20 lb
Top Balance Size (C.F)	6BRD
Top Balance Size (Spiral)	21-7B
Bottom Sash Weight	17 lb
Bottom Balance Size (C.F)	5MAT
Bottom Balance Size (Spiral)	25-6R
Egress Opening Width	24.0940
Egress Opening Height	20.0000
Egress Opening Area (sq.ft.)	3.5460

Min. W: 11	Max. W: 52	
Min. H: 20	Min. H: 84	Max. U: 132

Exact Size

Width:	28.5	28.5
Height:	53.5	53.5

Exclusion: Select Exclusion << For Arch-Top Models Only

Opening: Exact Size

Type: Standard

Screen: #14

Glass: Double Strength (3 mm)

AC Sash Operator

*

* $24.8 \times 50.5 = 1252 \div 144 = 8.3 \text{ sq ft}$