

RECEIVED

JAN 26 2011

CITY CLERK

APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560



JAN 25 2011

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 2-1-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Mail

Address Being Appealed:

Number & Street: 409 Otis Ave City: St. Paul State: MN Zip: 55104

Appellant/Applicant: Ed & Beverly Kaye Email _____

Phone Numbers: Business _____ Residence 651-646-0406 Cell _____

Signature: _____ Date: _____

Name of Owner (if other than Appellant): Renewal by Andersons - Attn: Bryan Horton

Address (if not Appellant's): 1920 W City Rd C Roseville MN 55113

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 1 replacement casement window that will not comply w/ Egress Policy. Opening width is 18.5"; 1.5" short of the required operable width. Other criteria is exceeded. Brick openings prevent any alteration. Please Approve.

Revised 8/20/2010



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: January 19, 2011

APPEAL PROPERTY ADDRESS: 409 OTIS AVE
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-266-9071
PERMIT NUMBER: 11 007165
TYPE OF WINDOW: Double Casement
NUMBER OF WINDOWS: 1

Total Glazed Area Minimum 5 Square Feet	17.7	Difference from Required Area	+12.7
Width of Opening Minimum 20 Inches	18.5	Difference from Required Opening	-1.5
Height of Opening Minimum 24 Inches	47 ¾	Difference from Required Opening	+23 ¾
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	36	Difference from Maximum Height	ok

COMMENTS: With the information provided above approval is recommended. 1-19-11 rr

Reviewed by: Rehn