



October 25, 2023

Alisher Musinov
5008 W 109th St
Bloomington MN 55437-3008

Order to Abate Nuisance Building(s)

Dear Responsible or Interested Party:

The Vacant/Nuisance Buildings Unit, Department of the Department of Safety and Inspections, Division of Code Enforcement, hereby declares the premises located at:

59 KING ST E

With the following Historic Preservation information: NONE

and legally described as follows, to wit:

WEST ST PAUL BLKS 100 THRU,171 W 1/2 OF E 2/3 OF LOTS 6 AND 7 AND W ...E 2/3 OF S
1/2 OF LOT 8 BLK 107

to comprise a nuisance condition in violation of the Saint Paul Legislative Code, Chapter 45.02, and subject to demolition under authority of Chapter 45.11.

On October 11, 2023, a Building Deficiency Inspection Report was compiled and the following conditions were observed.

This list of deficiencies is not necessarily all the deficiencies present at this time. This building(s) is subject to the restrictions of Saint Paul Ordinance Chapter 33.03 and shall not again be used for occupancy until such time as a Certificate of Compliance or a Certificate of Occupancy has been issued. All repairs must be in accordance with appropriate codes. Changes or additions to the electrical system, mechanical system, or the plumbing system may necessitate updating or upgrading the systems involved.

This is a two story, wood frame, single-family dwelling with a detached one-stall garage.

The following is excerpted from the April 25, 2023 expired Code Compliance Report:

BUILDING

1. Ensure basement cellar floor is even, is cleanable, and all holes are filled.
2. Repair or replace damaged doors and frames as necessary, including storm doors.

3. Weather seal exterior doors, threshold, and weather-stripping.
4. Repair walls, ceiling, and floors throughout, as necessary.
5. Prepare and paint interior and exterior as necessary. Observe necessary abatement procedures (EPA, MPCA and St. Paul Legislative Code, Chapter 34 for additional information) if lead base paint is present.
6. Any framing members that required repair or do not meet code (where wall and ceiling covering is removed, members that are over-spanned, over-spaced, not being carried properly, door and window openings that are not adequately supported, etc.) are to be reconstructed in an approved manner.
7. Where wall and ceiling covering is removed install full thickness or code-specified insulation.
8. Air-seal and insulate attic/access door.
9. Install Smoke Detectors/Carbon Monoxide Detectors per MN Conservation Code and the MN Dept. of Labor and Industry: Install per code where feasible.
10. Verify proper venting of bath exhaust fan to exterior.
11. Provide weather sealed, air sealed and vermin sealed exterior.
12. Tuck Point interior/exterior of foundation as necessary.
13. Install rain leaders to direct drainage away from foundation.
14. Replace garage roof covering and vents to code.
15. Provide general rehabilitation of garage.
16. Remove trees which are against foundation of home and garage.
17. Windows installed without a permit. Ensure all windows are installed to code.
18. Repair front entry porch.
19. Dry out basement and eliminate source of moisture.
20. Remove mold, mildew and moldy or water damaged materials.
21. Remove or encapsulate asbestos in an approved manner.
22. Install handrails (34 inches - 38 inches above each nosing) and guardrails (36 inch minimum) at all stairways, and return handrail ends into a newel post or wall per attachment.
23. Strap or support top of stair stringers for structural stability.
24. Provide functional hardware at all doors and windows.
25. Exit doors shall be capable of being opened from the inside, easily and without the use of a key. Remove all surface bolts.
26. A building permit is required to correct the above deficiencies. All work is to be done in a workmanship like manner.

ELECTRICAL

1. Repair the electrical service grounding conductor to the metallic water piping system. Install a conductor sized to Table 250.66 (NEC) from the electrical service to within 5' of the entrance point of the water service, and bond around the water meter.
2. Provide a complete circuit directory at service panel indicating location and use of all circuits.

3. Verify that fuse/circuit breaker amperage matches wire size in panel. Replace improperly sized overcurrent devices.
4. Install hard-wired smoke detector as specified in Chapter 58 of the Saint Paul Legislative Code, and other smoke detectors and carbon monoxide detectors as required by the Minnesota State Building Code.
5. Throughout -Ensure/rewire all electrical associated with NM cables dated after 2014 to current NEC. An electrical permit was never purchased for that wiring.
6. Throughout -Remove and/or rewire all illegal, improper, or hazardous wiring to current NEC.
7. Throughout - All wiring must be inspected before it is concealed, the person responsible for concealing the wiring is responsible for all costs associated with removal and replacement of the covering material. All equipment grounding conductors and other conductors in boxes must be spliced and pigtailed before scheduling a rough-in inspection.
8. Throughout -Close openings in service panel/junction boxes with knockout seals, breaker blanks, proper cable clamps, and/or junction box covers.
9. Throughout -Repair or replace all broken, painted over, corroded, missing or loose receptacles, luminaires (light fixtures), switches, covers and plates to current code.
10. Throughout -Check all receptacles for proper polarity (including 2-prong) and verify ground on 3-prong receptacles. Ensure all GFCI receptacles are functioning properly. Rewire and/or replace receptacles that are improperly wired or not functioning properly.
11. Throughout -Install box extensions on devices.
12. All electrical work must be done by a Minnesota-licensed electrical contractor under an electrical permit.

PLUMBING

1. Basement -Laundry Tub - Install a proper fixture vent to code.
2. Basement -Laundry Tub - Install the waste piping to code.
3. Basement -Soil and Waste Piping - Install a front sewer clean out.
4. Basement -Soil and Waste Piping - Install a clean out at the upper terminal at each horizontal drainage pipe.
5. Basement -Water Heater - Install the water heater gas venting to code.
6. Basement -Water Heater - The water heater venting requires a chimney liner.
7. Basement -Water Heater -The water heater must be fired and in service.
8. Basement -Water Meter -Raise the water meter to a minimum of 12 inches above the floor.
9. Basement -Water Meter - Support the water meter to code.
10. Basement -Water Meter - The service valves must be functional and installed to code.
11. Basement -Water Piping -Repair or replace all the corroded, broken, or leaking water piping.
12. Basement -Water Piping - Provide water piping to all fixtures and appliances.
13. Basement -Water Piping - Provide a one (1) inch water line to the first major take off.

14. Exterior -Lawn Hydrants - Repair or replace the lawn hydrants that are broken or have parts missing.
15. First Floor -Gas Piping - Replace corroded gas piping/fittings.
16. First Floor -Gas Piping - Replace improper piping or fittings.
17. First Floor -Gas Piping - Install an approved shut off; connector and gas piping for the range.
18. First Floor -Gas Piping - Install an approved shut off; connector and gas piping for the dryer.
19. First Floor -Gas Piping - Vent clothes dryer to code.
20. First Floor -Lavatory - Install a proper fixture vent to code.
21. First Floor -Lavatory - Install the waste piping to code.
22. First Floor -Lavatory - Repair/replace the fixture that is missing, broken or has parts missing.
23. First Floor -Lavatory - Repair/replace the faucet that is missing, broken or has parts missing.
24. First Floor -Sink - Install a proper fixture vent to code.
25. First Floor -Sink - Install the waste piping to code.
26. First Floor -Sink - Repair/replace the fixture that is missing, broken or has parts missing.
27. First Floor -Sink - Repair/replace the faucet that is missing, broken or has parts missing.
28. First Floor -Toilet Facilities - Install a proper fixture vent to code.
29. First Floor -Toilet Facilities - Install the waste piping to code.
30. First Floor -Toilet Facilities - Repair/replace the fixture that is missing, broken or has parts missing.
31. First Floor -Toilet Facilities - Repair/replace the faucet that is missing, broken or has parts missing.
32. First Floor -Tub and Shower - Install a proper fixture vent to code.
33. First Floor -Tub and Shower - Install the waste piping to code.
34. First Floor -Tub and Shower - Repair/replace the fixture that is missing, broken or has parts missing.
35. First Floor -Tub and Shower - Repair/replace the faucet that is missing, broken or has parts missing.
36. All the above corrections to waste, vent, water, and gas piping shall be per the Minnesota Plumbing Code Chapter 4714, Minnesota Rules Chapter 326, 4716, 1300, the Minnesota Mechanical Code, the Minnesota Fuel Gas Code, and Saint Paul Regional Water Services Water Code. All plumbing must be done by a plumbing contractor licensed in the State of Minnesota and the City of St. Paul by a plumber licensed in the State of Minnesota who also possess a City of Saint Paul Competency Card and after obtaining an approved City of Saint Paul Plumbing Permit.

MECHANICAL

1. Install approved level handle manual gas shutoff valve on furnace/boiler and remove unapproved valve.
2. Connect furnace/boiler and water heater venting into chimney liner.

October 25, 2023

59 KING ST E

Page 5

3. Vent clothes dryer to code.
4. Provide support for gas lines to code.
5. Plug, cap and/or remove all disconnected gas lines.
6. Repair and/or replace heating registers as necessary.
7. Provide heat in every habitable room and bathrooms.
8. Air test required for new CSST kitchen range piping.
9. Furnace copper gas line cannot contact ductwork.
10. Provide a means of returning air from every habitable room to the furnace. Return air cannot be taken from closets, bathrooms, toilet rooms, kitchen, or mechanical rooms.
11. Provide a means of draining furnace condensate per code.
12. Mechanical permits are required for the above work.

As owner, agent, or responsible party, you are hereby notified that if these deficiencies and the resulting nuisance condition is not corrected by **November 24, 2023**, the Department of Safety and Inspections, Division of Code Enforcement, will begin a substantial abatement process to demolish and remove the building(s). The costs of this action, including administrative costs and demolition costs will be assessed against the property taxes as a special assessment in accordance with law.

As first remedial action, a Code Compliance Inspection Report must be obtained from the Building Inspection and Design Section, 375 Jackson Street, Suite 220, (651) 266-8989. This inspection will identify specific defects, necessary repairs, and legal requirements to correct this nuisance condition. You may also be required to post a five thousand dollars (\$5,000.00) performance deposit with the Department of Safety and Inspections before any permits are issued, except for a demolition permit. Call the Department of Safety and Inspections for more information at 651-266-8989.

If this building is located in a historic district or site (noted on page 1, above, just below the property address) then you must contact Heritage Preservation (HPC) staff to discuss your proposal for the repairs required by this order and compliance with preservation guidelines. Copies of the guidelines and design review application and forms are available from the Department of Safety and Inspections web site (see letterhead) and from the HPC staff. No permits will be issued without HPC review and approval. HPC staff also can be reached by calling 651-266-9078.

As an owner or responsible party, you are required by law to provide full and complete disclosure of this "Order to Abate" to all interested parties, all present or subsequent renters and any subsequent owners. The property shall not be sold, transferred, or conveyed in any manner until the Nuisance Conditions have been abated and the Certificate of Code Compliance or Certificate of Occupancy has been issued.

The Enforcement Officer is required by law to post a placard on this property which declares it to be a "nuisance condition", subject to demolition and removal by the City. This placard shall not be removed without the written authority of the Department of Safety and Inspections, Division of Code Enforcement. The department is further required to file a copy of this "Order to Abate" with the City Clerk's Office.

If corrective action is not taken within the time specified in this order, the Enforcement Officer will notify the City Council that abatement action is necessary. The City Clerk will then schedule dates for Public Hearings before the City Council at which time testimony will be heard from interested parties. After this hearing the City Council will adopt a resolution stating what action if any, it deems appropriate.

If the resolution calls for abatement action the Council may either order the City to take the abatement action or fix a time within which this nuisance must be abated in accordance with the provisions of Chapter 33 of the Saint Paul Legislative Code and provide that if corrective action is not taken within the specified time, the City shall abate this nuisance. The costs of this action, including administrative costs will be assessed against the property as a special assessment in accordance with law.

If you have any questions or request additional information, please contact **Joe Yannarely** at **651-266-1920**, or you may leave a voicemail message.

Sincerely,

Joe Yannarely

Vacant Buildings Enforcement Inspector