



APPLICATION FOR APPEAL

Saint Paul City Council – Legislative Hearings

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8585

RECEIVED

AUG 15 2014

CITY CLERK

We need the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
 - Copy of the City-issued orders/letter being appealed
 - Attachments you may wish to include
 - This appeal form completed
 - Walk-In OR Mail-In
- for abatement orders only: Email OR Fax

HEARING DATE & TIME (provided by Legislative Hearing Office) Tuesday, <u>August 26, 2014</u>
Time <u>11:00 a.m.</u>
Location of Hearing: Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 537 Mt. Curve Blvd City: St. Paul State: MN Zip: 55114

Appellant/Applicant: JOHN GOODMAN Email: john.c.goodman@comcast.net

Phone Numbers: Business _____ Residence 651-699-2009 Cell _____

Signature: John Goodman Date: 8-15-2014

Name of Owner (if other than Appellant): _____

Mailing Address if Not Appellant's: _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

Does not need an inspection,
The request does not seem to
make sense.



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

August 8, 2014
SHARON GOODMAN
JOHN GOODMAN
2197 SCHEFFER AVE
ST PAUL MN 55116-1161

Revocation of Fire Certificate of Occupancy and Order to Vacate

RE: 537 MOUNT CURVE BLVD
Ref. # 121040

Dear Property Representative:

Your building was inspected on August 8, 2014, for the renewal of the Certificate of Occupancy. Since you have failed to comply with the applicable requirements, it has become necessary to revoke the Certificate of Occupancy in accordance with Section 40.06 of the Saint Paul Legislative Code. A reinspection will be made on August 18, 2014 at 10:30am or the property vacated.

The Saint Paul Legislative Code further provides that no building shall be occupied without a Certificate of Occupancy. Failure to immediately complete the following deficiency list or the building vacated may result in a criminal citation.

DEFICIENCY LIST

1. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
2. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.
3. SPLC 34.19 - Provide access to the inspector to all areas of the building.-

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: adrian.neis@ci.stpaul.mn.us or call me at 651-266-8992 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Adrian Neis
Fire Inspector

Ref. # 121040



By Order of the
City of Saint Paul
Department of Safety & Inspections
Fire Inspection Division
651- 266- 8989



REVOCAATION NOTICE

The Fire Certificate of Occupancy required for the
Occupancy or Use of This Building, has been Revoked.

It is unlawful to Use or Occupy this building

After: 8-18-14.

Persons Using or Allowing the Use or Occupancy of
This Building, are Subject to Criminal Penalties.

Building Address: 537 Mt. Curve

Code: SP60, Art.: 40, Sect. _____.

Inspector: _____, Date: 8-15-14.

Under Penalty of Law, this notice shall not be removed without authorization from the
Department of Safety & Inspections

Any Person affected by this Order, may file an appeal at the Office of the City Clerk,
Room 310, City Hall, 15 Kellogg Blvd. West, or call (651) 266-8688 within 10 days
of the original notice. The cost to file an appeal is \$25. and must include a copy
of the letter of Revocation. This letter of Revocation is available at: Saint Paul Department
of Safety & Inspections, Fire Inspection Division, 375 Jackson Street Suite #220 Saint Paul, MN 55101