



APPLICATION FOR APPEAL

RECEIVED

APR 11 2012

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed *mail*

YOUR HEARING Date and Time:

Tuesday, 4-17-12

Time 1:30 P.M.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1540 PASCAL ST City: ST. PAUL State: MN Zip: 55108

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: 04/02/12

Name of Owner (if other than Appellant): Jeff Pounds

Address (if not Appellant's): 1540 Pascal Street

Phone Numbers: Business _____ Residence 651-278-1844 Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 3 replacement windows that will not comply w/ egress policy. Current openings will be short by 5" in operable height. Shortcome in height is offset by an excess in operable width of 4". Please Approve.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: April 5, 2012

APPEAL PROPERTY ADDRESS: 1540 PASCAL ST N

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 12 040833

TYPE OF WINDOW DOUBLE HUNG

NUMBER OF WINDOWS 6

Total Glazed Area Minimum 5 Square Feet	6.3	Difference from Required Area	+1.3
Width of Opening Minimum 20 Inches	24	Difference from Required Opening	+4
Height of Opening Minimum 24 Inches	19	Difference from Required Opening	-5
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	<48	Difference from Maximum Height	OK

COMMENTS:

Reviewed by: R. Rehn