



**CITY OF SAINT PAUL**  
OFFICE OF THE CITY COUNCIL  
310 CITY HALL  
15 WEST KELLOGG BOULEVARD  
SAINT PAUL, MN 55102-1615  
EMAIL: [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us)  
PHONE: (651) 266-8560 FAX: (651) 266-8574

November 1, 2010

Brian Bennett  
Pella Windows & Doors  
15300 – 25<sup>th</sup> Ave N  
Plymouth, MN 55447

VIA EMAIL: [bennettbs@pella.com](mailto:bennettbs@pella.com)

Re: Appeal for property at 1153 Hawthorne Avenue East.  
File ID: ALH 10-308

Dear Mr. Bennett:

This is to confirm that on October 28, 2010, Marcia Moermond, Legislative Hearing Officer reviewed your appeal in the above-referenced matter and recommended granting a 2.75-inch variance on the openable height of three double hung replacement egress bedroom windows measuring 21.25 inches high by 20 inches wide.

If you have any questions, you may contact me at 651-266-8563.

Sincerely,

/s/

Mai Vang  
Paralegal

cc: Fire Supervisors (email)  
Pat Fish (email)  
Jim Bloom (email)  
Ryan Rehn (email)  
Stephen Ubl (email)



