

STAMP - Activity Detail[New Search](#)[Help using this report](#)[E-mail Service Desk](#)**817 Aldine St**

Click [here](#) to access other applications using this address - GISmo, MapIT, and Ramsey County Info

Run Date: 09/16/11 09:04 AM**Folder:** 10 926274**In Date:** 11/23/10**Issued Date:** 11/23/10**ID#:****Status:** Inspected**Expiry Date:** 05/22/11**Closed:****Type:** B - Building Permit - Single Family Dwelling - Repair**Condition:**

FIRE INSPECTION LIST FOR GARAGE ROOF FLASHING, SOFFIT, FLOOR AND WINDOWS STRUCTURAL PLAN REVIEW, fb, 11/23/10: Sign-off is with the understanding that the building's structural components are already up. I was asked by the DSI senior inspector to determine if the portion of the floor that was originally to be concrete slab could instead be wood framing and still be considered part of the permanent structure. Following a meeting with the owner I determined that along with the existing reinforced concrete grade beams wood framing was structurally acceptable.

Comment:

12/10/2010 Stephen Ubl: 12/10/2010: General Inspection - Partial Approval. Roof flashing appears complete. Soffits, landings and window sills are not complete
07/01/2011: Final Inspection - Corrections Required. weather seal around windows and doors. Remove toe-holds on roof. Abandon function of rear door or build landing/stairs

People:

Owner:

John F Krenik
1270 Cleveland Ave S
St Paul MN 55116-2601
651-699-6555

Contractor:

John F Krenik
1270 Cleveland Ave S
St Paul MN 55116-2601
651-699-6555

Property:

817 ALDINE ST, PIN: 282923430026

Info Value:

Penalty Fee: No
Change/Expansion of Use?: No
Existing Primary Use (Single Family): R-Single Family Dwelling
of Existing Dwelling Units: 1
Estimated Value of Work: \$500.00
State Valuation: \$500.00
Valuation Override: No
Scope of Repair Work : Minor Repair
Structural Work?: No Structural Work
Interior/Exterior?: Exterior Only
Plan Number: V-2010-2136
Type of Plan: V-Vertical File
Plan Check Fee: Hourly PC Fee
Electrical Permit Required?: No
WAir/Ventilation Permit Req'd?: No
Plumbing Permit Required?: No
Sprinkler Permit Required?: No
Mechanical Permit Required?: No
Field Application?: No
Surcharge Report Valuation: \$1,000.00

Fee:

Building Permit Fee: \$28.60 - Paid in Full: Yes - Payment Type: Check - Payment Date: 11/23/2010
Surcharge B: \$0.50 - Paid in Full: Yes - Payment Type: Check - Payment Date: 11/23/2010
Parks Dedication Fee (DC 11): \$0.00 - Paid in Full: Yes - Payment Type: Check - Payment Date:

11/23/2010

Front Counter

Assigned To: Lee, Zoua

Closed: 11/23/10

Result:

11/23/2010: Approved

Architectural (R) Review

Assigned To: Hruska, Robert

Comment: V-2010-2136

Closed: 11/23/10

Result:

11/23/2010: Preliminary Plan Check

11/23/2010: Approved

Building Permit Inspection

Assigned To: Ubl, Stephen

Inspection Date: 12/10/10

Inspection 1:

Type: General Inspection

Result: Partial Approval

Comment: Roof flashing appears complete. Soffits, landings and window sills are not complete

Closed: 12/10/10

Inspection Date: 07/01/11

Inspection 1:

Type: Final Inspection

Result: Corrections Required

Comment: weather seal around windows and doors. Remove toe-holds on roof. Abandon function of rear door or build landing/stairs

Closed: 07/01/11

Assigned To: Barck, Mike

Next Schedule: 07/20/11