

## CITY OF SAINT PAUL

OFFICE OF THE CITY COUNCIL 310 CITY HALL 15 WEST KELLOGG BOULEVARD SAINT PAUL, MN 55102-1615

EMAIL: <u>legislativehearings@ci.stpaul.mn.us</u> PHONE: (651) 266-8560 FAX: (651) 266-8574

March 9, 2011

David Palmer PO Box 7028 Minneapolis, MN 55407

VIA EMAIL: djprealestate@aol.com

Re: Appeal for property at 1609 Saint Anthony Avenue

File ID: ALH 11-169

Dear Mr. Palmer:

This is to confirm that on February 8, 2011, at the Property Code Hearing, Marcia Moermond, Legislative Hearing Officer recommended the following:

- 1. Grant a 4.5-inch variance on the openable height of the egress bedroom window in Unit 5 which measured at 19.5 inches high by 27 inches wide.
- 2. Items 3 (fire separation) and 4 (sprinkler system issue) deny the appeal. (must decide to come into compliance with one of the two items.
- 3. Items 7 (water heater issue) and 55 (boiler) Must install a chimney liner under permit.
- 4. A separate permit is not needed on boiler and water heater installation.

If you have further questions, please contact me at 651-266-8563.

Sincerely, /s/

Mai Vang Legislative Hearing Coordinator

c: Fire Supervisors (email)
Pat Fish (email)
File