



APPLICATION FOR APPEAL

Saint Paul City Council – Legislative Hearings

RECEIVED

NOV 01 2016

CITY CLERK

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8585

We need the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
 - Copy of the City-issued orders/letter being appealed
 - Attachments you may wish to include
 - This appeal form completed
 - Walk-In OR Mail-In
- for abatement orders only: Email OR Fax

HEARING DATE & TIME (provided by Legislative Hearing Office) Tuesday, <u>Nov. 8, 2016</u>
Time <u>1:30 p.m.</u>
Location of Hearing: Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 287 Robie Street E City: St. Paul State: MN Zip: 55107

Appellant/Applicant: Linda Vang Email: vanglinda86@gmail.com

Phone Numbers: Business _____ Residence _____ Cell 612-247-9021

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): _____

Mailing Address if Not Appellant's: 2655 South Ave E
North St. Paul, MN 55109

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? Attachments Are Acceptable

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other _____

Home stead home of 287 Robie street East on record as rental property. This is my primary home, not a rental property.



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

October 18, 2016

LINDA VANG
2655 SOUTH AVE E
MAPLEWOOD MN 55109-3312

RE: RE-INSPECTION FIRE CERTIFICATE OF OCCUPANCY WITH DEFICIENCIES
287 ROBIE ST E Ref. # 122493

Your building was re-inspected for the Fire Certificate of Occupancy on October 17, 2016. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected immediately.

A reinspection will be made on November 7, 2016 at 10 am.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

1. EXTERIOR - BRUSH / TREE BRANCH - MSFC 304.1 - Remove excessive combustible storage and/or vegetation from exterior property areas.-Remove the brush pile from the backyard and down tree branch
2. EXTERIOR - HOLE IN SIDING - SPLC 34.09 (1) b,c, 34.33 (1) b, c - Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint.-Repair or replace the hole in siding by the side door, needs to be maintained
3. INTERIOR - DRYER VENT - MSMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter and installed in accordance with the mechanical code. This work require a permit(s). Call DSI at (651) 266-8989.
4. INTERIOR - HARDWIRE - MN Stat. 299F.362 - Immediately provide and maintain a smoke detector located outside each sleeping area.-Maintain the hardwire detector in the basement, currently a battery only is there in place of hardwire.

5. INTERIOR - KITCHEN SINK FLOORING - SPLC 34.10 (7), 34.34 (6) - Repair and maintain the floor in an approved manner.-Repair or replace the floor covering under the lower kitchen sink. Wood is rotten from past water damage

6. OWNER - CLASS - SPLC 40.04 (5) The owner of a building used for residential occupancy who is applying for their FIRST Fire Certificate of Occupancy, must complete the Department of Safety and Inspection Landlord 101 course, or other landlord training program approved by the Department of Safety and Inspections. The training must have occurred within the last two years and the owner must submit a certificate of attendance or provide verification of enrollment in the next scheduled class to the Fire Inspection Division-DSI. This requirement shall not apply to an owner who has held a Fire Certificate of Occupancy on another residential property in Saint Paul prior to April 30, 2009. For more information on Landlord 101, or to receive registration materials, please visit our webpage at: www.stpaul.gov/cofo

Or, contact Fire Safety Inspector Leanna Shaff by email: leanna.shaff@ci.stpaul.mn.us

7. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.

8. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at Jonathan.Gaulke@ci.stpaul.mn.us or call me at 651-266-8994 between 7:30 a.m - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,
Jonathan Gaulke
Fire Inspector
Ref. # 122493