



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

RECEIVED

NOV 8 2011

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 11-22-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

e mailed Notice 11-8-11

Address Being Appealed:

Number & Street: 555 Saratoga City: St. Paul State: MN Zip: 55116

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): Tony Baligalupi

Address (if not Appellant's): 555 Saratoga St S

Phone Numbers: Business _____ Residence 651-695-0927 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing bedroom windows that will not comply w/ Egress Policy. operable height will be 18". Other criteria will be met or exceeded. Please Approve



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 31, 2011

APPEAL PROPERTY ADDRESS: 555 SARATOGA ST S
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-264-4914
PERMIT NUMBER: 11 294694
TYPE OF WINDOW Double Hung
NUMBER OF WINDOWS 1

Total Glazed Area Minimum 5 Square Feet	7.8	Difference from Required Area	+2.8
Width of Opening Minimum 20 Inches	24	Difference from Required Opening	+4
Height of Opening Minimum 24 Inches	23	Difference from Required Opening	-1
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	<48	Difference from Maximum Height	ok

COMMENTS: NA

Reviewed by: Rehn



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 31, 2011

APPEAL PROPERTY ADDRESS: 555 SARATOGA ST S

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 11 294694

TYPE OF WINDOW Double hung

NUMBER OF WINDOWS 1

Total Glazed Area Minimum 5 Square Feet	7	Difference from Required Area	+2
Width of Opening Minimum 20 Inches	28	Difference from Required Opening	+8
Height of Opening Minimum 24 Inches	18	Difference from Required Opening	-6
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	<48	Difference from Maximum Height	ok

COMMENTS: NA

Reviewed by: Rehn