

RECEIVED

OCT 25 2010

CITY CLERK

APPLICATION FOR APPEAL



Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, NOV. 2

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1280 Eleanor Ave City: St. Paul State: MN Zip: 55116

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): Diane Mancini

Address (if not Appellant's): 1280 Eleanor Ave

Phone Numbers: Business _____ Residence 651-698-1028 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing a total of 6 replacement bedroom windows that will not comply w/ the St. Paul Egress Policy. 5 windows will be short in operable height by 1 3/8". The 1 other window will be short in operable height by 6 3/8". All 6 will exceed minimal width opening by 4". Homeowner wants to keep existing style. Please Approve.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 21, 2010

APPEAL PROPERTY ADDRESS: 1280 ELEANOR AVE

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-266-9071

PERMIT NUMBER: 10 913114

TYPE OF WINDOW DOUBLE HUNG

NUMBER OF WINDOWS 1

Total Glazed Area	8.3 sq.ft	Difference from Required Area	+ 3.3 sq.ft
Width of Opening	24"	Difference from Required Opening	+ 4"
Height of Opening	17 5/8"	Difference from Required Opening	- 6 3/8"
Height of Opening to Finished Floor	OK	Difference from Maximum Height	OK

COMMENTS: Based on information provided above determination will be made by the legislative hearing officer

Reviewed by: jps



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 21, 2010

APPEAL PROPERTY ADDRESS: 1280 ELEANOR AVE
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-266-9071
PERMIT NUMBER: 10 913114
TYPE OF WINDOW: DOUBLE HUNG
NUMBER OF WINDOWS: 5

Total Glazed Area	10.2 sq.ft	Difference from Required Area	+ 5.2 sq.ft.
Width of Opening	24"	Difference from Required Opening	+ 4"
Height of Opening	22 5/8"	Difference from Required Opening	- 1 3/8"
Height of Opening to Finished Floor	OK	Difference from Maximum Height	OK

COMMENTS: Base on information provided above determination to be made by the legislative hearing officer

Reviewed by: jps