



APPLICATION FOR APPEAL

RECEIVED

Saint Paul City Clerk

APR 14 2011 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102

CITY CLERK

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 4-19-11

Time 1:30

Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 896 Como Ave City: St. Paul State: mn Zip: 55103

Appellant/Applicant: Renewal by Andersen Email: bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): Harriet Marks

Address (if not Appellant's): 896 Como Ave St. Paul, MN 55103

Phone Numbers: Business _____ Residence 651-487-6282 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing to replacement windows that will not comply w/ Egress Policy. Operable height will be short by 3". Largest operable window in the room. Windows are all grouped together, pictures included. Please Approve.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: April 8, 2011

APPEAL PROPERTY ADDRESS: 896 COMO AVE

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 11 127495

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 6

Total Glazed Area Minimum 5 Square Feet	8.5	Difference from Required Area	+3.5
Width of Opening Minimum 20 Inches	21	Difference from Required Opening	+1
Height of Opening Minimum 24 Inches	21	Difference from Required Opening	-3
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	36	Difference from Maximum Height	ok

COMMENTS: With the information provided above, approval is recommended. 4-8-11 rr

Reviewed by: Rehn

