



CITY OF SAINT PAUL  
*Christopher B. Coleman, Mayor*

100 East 11<sup>th</sup> Street  
Saint Paul, MN 55101

Telephone: 651-228-6230

February 12, 2008

TAIB K ANSERA  
1099 CUMBERLAND ST  
ST PAUL MN 55117-4870

RE: FIRE CERTIFICATE OF OCCUPANCY APPROVAL WITH DEFICIENCIES  
1133 ARUNDEL ST

Ref. # 110695

Dear Property Representative:

Your building was inspected on February 12, 2008 for the renewal of the Fire Certificate of Occupancy and was approved with deficiencies. When the required fee has been received you will receive your certificate.

The following deficiencies must be corrected immediately. A reinspection will be made on or after 2-29-08 Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy.

#### DEFICIENCY

2. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.-permit has been pulled by contractor for new furnace, but needs inspection and signoff. call 266-9044 for inspection.

If you have any questions, call me at 651-228-6205 between 7:30 a.m. - 9:00 a.m.

Sincerely,

Pat Fish  
Fire Inspector

Ref. # 110695