



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

No. 0443 P. 4

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: 4-24-12

APPEAL PROPERTY ADDRESS: 1131 Jessie #1

APPLICANT NAME: PUBLIC HEALTH (DANIEL SCHMIDT) PHONE NUMBER: 266-1143

PERMIT NUMBER: \_\_\_\_\_

TYPE OF WINDOW: DOUBLE HUNG

NUMBER OF WINDOWS: 1

TOTAL GLAZED AREA: 8.2 sq ft DIFFERENCE FROM REQUIRED AREA: COMP

WIDTH OF OPENING: 17.2" DIFFERENCE FROM REQUIRED OPENING: 2.8"

HEIGHT OF OPENING: 27.9" DIFFERENCE FROM REQUIRED OPENING: COMP

HEIGHT OF OPENING ABOVE FINISHED FLOOR: 48" DIFFERENCE FROM MAXIMUM HEIGHT: COMP

RECOMMENDATION (IF APPLICABLE): \_\_\_\_\_

RECEIVED  
APR 24 2012  
CITY CLERK

Apr. 24. 2012 1:16PM

FROM: \_\_\_\_\_

No. 0443 P. 5

St Paul-Ramsey Co. Public Health

Apr. 24, 2012 1:16PM

Select a Model

(Model 0201) Excaltibur Double Hung		Min. W: 11 Min. H: 20	Max. W: 52 Min. H: 84	Max. H: 132
Top Sash Width	18.3750	Exact Size		
Top Sash Height	33.1250	Width: 21.625	21.625	
Bottom Sash Width	19.3750	Height: 69.325	69.325	
Bottom Sash Height	34.0750	Extrusion: Select Extrusion << For Arched-Top Models Only		
Top Glass Width	16.6375	Opening: Exact Size		
Top Glass Height	51.4375	Type: Standard		
Bottom Glass Width	17.6875	Screen: Full		
Bottom Glass Height	32.3750	Glass: Double Strength (3mm)		
Screen Width	17.9375	<input type="checkbox"/> AC Stub Calculator		
Screen Height	66.4375			
Top Sash Weight (Plus 5 lb)	21 lb			
Top Balance Size (C.F.)	56BU			
Top Balance Size (Springs)	29-9R			
Bottom Sash Weight	17 lb			
Bottom Balance Size (C.F.)	56AT			
Bottom Balance Size (Springs)	33-5R			
Egress Opening Width	17.2180			
Egress Opening Height	27.9375			
Egress Opening Area (sq. ft.)	3.5440			

1131 JESSIE #1