



CITY OF SAINT PAUL

## Code Compliance Report

July 30, 2021

**\*\* This Report must be Posted  
on the Job Site \*\***

Charles Nosie  
12200 Upper Heather Ave N  
Hugo MN 55038-9394

Re: 331 Lawson Ave W  
File#: 21 236473 VB2

Dear Property Owner:

The following is the Code Compliance report you requested on June 24, 2021.

Please be advised that this report is accurate and correct as of the date July 30, 2021. All deficiencies identified by the City after this date must also be corrected and all codes and ordinances must be complied with. This report is valid for 365 days from July 30, 2021. This report may be used in lieu of a Truth in Housing Report required in St Paul Legislative Code 189. This building must be properly secured and the property maintained at all times.

In order to sell or reoccupy this property the following deficiencies must be corrected. A Legislative Code exemption (Chapter 33.03(f)) allows a Category 2 Vacant Building to be sold "as is" providing the buyer, prior to closing, completes an approval process. For further information, call Reid Soley at 651-266-9120.

### **ZONING**

1. This property is in a(n) R4 zoning district.
2. The property was inspected as a Duplex.

**This property was inspected as a Duplex which is not permitted in this zoning district; this property may be a non-conforming use and will require zoning approval before a sale can be approved, any permits may be issued or any work on the property is started.**

**BUILDING Inspector: Nathan Bruhn**

**Phone: 651-266-9033**

1. Insure basement cellar floor is even, is cleanable, and all holes are filled. SPLC 34.10 (1)
2. Repair or Replace any deteriorated window sash, broken glass, sash holders,

- re-putty, etc as necessary. SPLC 34.09 (3)
3. Provide complete storms and screens, in good repair for all door and window openings. SPLC 34.09 (3e)
  4. Provide functional hardware at all doors and windows. SPLC 34.09 (3f)
  5. Exit doors shall be capable of being opened from the inside, easily and without the use of a key. Remove all surface bolts. SPLC 34.09 (3h)
  6. Repair or replace damaged doors and frames as necessary, including storm doors. SPLC 34.09 (3f)
  7. Weather seal exterior doors, threshold and weather-stripping. SPLC 34.09 (3f)
  8. Install floor covering in bathroom and kitchen that is impervious to water. SPLC 34.10 (4)
  9. Repair walls, ceiling and floors throughout, as necessary. SPLC 34.34 (6)
  10. Prepare and paint interior and exterior as necessary. Observe necessary abatement procedures (EPA, MPCA and St. Paul Legislative Code, Chapter 34 for additional information) if lead base paint is present. SPLC 34.33 (1)
  11. Any framing members that required repair or do not meet code (where wall and ceiling covering is removed, members that are over-spanned, over-spaced, not being carried properly, door and window openings that are not adequately supported, etc.) are to be reconstructed in an approved manner. SPLC 34.34 (1)
  12. Dry out basement and eliminate source of moisture. SPLC 34.10 (10)
  13. Charred building components shall be scraped or sandblasted completely clean and water-damaged components replaced. A determination of necessary fire damage corrective measures shall be made by this department or by a registered structural engineer as to replacement, repairs, etc. All smoke damaged and charred members shall be cleaned, sealed and deodorized. SPLC 34.09
  14. Provide fire block construction as necessary and seal chases in basement ceiling. MNRC Ch 1309 Sect. 602.8
  15. Where wall and ceiling covering is removed install full thickness or code-specified insulation. MN Energy Code Ch. 1322.1101 (except. 4)
  16. Air-seal and insulate attic/access door. MN Energy Code Ch 1322.1102.4
  17. Install Smoke Detectors/Carbon Monoxide Detectors per MN Conservation Code and the MN Dept. of Labor and Industry: Install per code where feasible. MNRC Ch 1309 Sect 313.2.1
  18. Provide major clean-up of premises. SPLC 34.34 (4)
  19. Install water-proof enclosure in shower area. MNRC Ch 1309 Sect. 307
  20. Provide weather sealed, air sealed and vermin sealed exterior. SPLC 34.32 (2)
  21. Replace or repair landing and stairway per code. SPLC 34.09 (2) This includes the rear deck stairway and the stairs to the cellar.
  22. Repair siding, soffit, fascia, trim, etc. as necessary. SPLC 34.09 (1)
  23. Remove mold, mildew and moldy or water damaged materials. SPLC 34.10 (1)
  24. Install downspouts and a complete gutter system. SPLC 34.33 (1d)
  25. Install rain leaders to direct drainage away from foundation. SPLC 34.33 (1d)
  26. Replace house and garage roof covering and vents to code. SPLC 34.09 (1)

27. Provide general rehabilitation of garage. SPLC 34.32 (3) Remove storage area in rafters and install an approved over head garage door.
28. Remove trees which are against foundation of home and garage. SPLC 34.09 (1b)
29. Openings in stair risers must be less than 4 inches. MNRC Ch. 1309 Sect. 311/312
30. Grade must drain away from foundation of dwelling. Maintain 6 inch clearance between wood and soil. MNRC Ch 1309-Sect. 404.1.6
31. Weather seal basement bulk head using approved materials. SPLC 34.09 (1b) Install an approved exterior rated door.
32. Cover water meter pit with concrete or decay resistant, screwed-down cover. Cleanouts to be flush with floor slab.
33. Provide adequate access, ventilation and clearance in crawl space area. MNRC Ch 1309 Sect. 408
34. Install 20 minute fire rated doors, with self closing device, between common areas and individual units. All penetrations required to have property intumescent device or caulk (per current building codes). MNRC Ch 1309 Sect. 317
35. Maintain one hour fire separation between dwelling units and between units and common areas. MNRC Ch 1309 Sect. 317
36. Install handrails (34 inches - 38 inches above each nosing) and guardrails (36 inch minimum) at all stairways, and return hand rail ends into a newel post or wall per attachment. MNRC Ch 1309 Sect. 311 & 312
37. A building permit is required to correct the above deficiencies. All work is to be done in a workmanship like manner. SPLC 33.03 (a)

**ELECTRICAL Inspector: Randy Klossner**

**Phone: 651 - 266 - 9032**

---

1. Repair the electrical service grounding conductor to the metallic water piping system. Install a conductor sized to Table 250.66 (NEC) from the electrical service to within 5' of the entrance point of the water service, and bond around the water meter. Article 250, NEC
2. Repair damaged electrical due to current NEC.
3. Provide a complete circuit directory at service panel indicating location and use of all circuits. Article 408.4, NEC
4. Verify that fuse/circuit breaker amperage matches wire size in panel. Replace improperly sized overcurrent devices. Article 240.4, NEC
5. Close openings in service panel/junction boxes with knockout seals, breaker blanks, proper cable clamps, and/or junction box covers. Article 110.12 (A), NEC
6. Repair or replace all broken, painted over, corroded, missing or loose receptacles, luminaires (light fixtures), switches, covers and plates to current code. Article 406.4(D) & Article 410, NEC
7. Check all receptacles for proper polarity (including 2-prong) and verify ground on 3-prong receptacles. Ensure all GFCI receptacles are functioning properly. Rewire and/or replace receptacles that are improperly wired or not functioning

- properly. Article 406.4(D), NEC
8. Install box extensions on devices mounted in wood paneling. Article 314.20, NEC
  9. Properly support/wire exterior luminaire (light fixture) at entry door. Articles 110.3 (B), 314.20, NEC
  10. Remove and/or rewire all illegal, improper or hazardous wiring to current NEC.
  11. All electrical work must be done by a Minnesota-licensed electrical contractor under an electrical permit.

**PLUMBING Inspector: Paul Zellmer**

**Phone: 651 - 266 - 9048**

---

1. Basement -Gas Piping -(MMC 103) Replace corroded gas piping/fittings.
2. Basement -Plumbing - General -(MN Rules Chapter 1300.0120) Obtain permits and provide tests/inspections for any plumbing performed without permits.
3. Basement -Plumbing - General -(MPC .0101 Subp. 6) Remove all unused waste, vent, water and gas piping to the main and cap or plug to code.
4. Basement -Soil and Waste Piping -(MPC 709.1) Install a front sewer clean out.
5. Basement -Soil and Waste Piping -(MPC 704 & 706) Replace all improper connections, transitions, fittings or pipe usage.
6. Basement -Soil and Waste Piping -(MPC .0100 M) Replace all corroded cast iron, steel waste or vent piping.
7. Basement -Water Heater -(MPC 507.5) Correct the pressure and temperature relief valve discharge.
8. Basement -Water Heater -(MFGC 503) Install the water heater gas venting to code.
9. Basement -Water Heater -(MPC 501)Install the water piping for the water heater to code.
10. Basement -Water Heater -(MPC .0100 Q)The water heater must be fired and in service.
11. Basement -Water Meter -(MPC 606.2) The service valves must be functional and installed to code.
12. Basement -Water Meter -(SPRWS Sec. 94.04 & 94.16(g)) The water meter must be removed from the pit.
13. Basement -Water Piping -(MPC 301.1 (3))Repair or replace all the corroded, broken, or leaking water piping.
14. Basement -Water Piping -(MPC 610) Replace all the improperly sized water piping.
15. Basement -Water Piping -(MPC .0100 P & Q) Provide water piping to all fixtures and appliances.
16. Bathroom -Plumbing - General -(MPC 402.2) Provide a water tight joint between the fixture and the wall or floor.
17. Bathroom -Plumbing - General -(MPC .0100 R, 402.1, 402.5, & 408.6) Provide proper fixture spacing.
18. Exterior -Lawn Hydrants -(MPC 301.1) Repair or replace the lawn hydrants that are broken or have parts missing.
19. First Floor -Gas Piping -(MFGC 411) Install an approved shut off; connector

and gas piping for the range.

20. First Floor -Lavatory -(MPC .0100 E & 901) Install a proper fixture vent to code.
21. First Floor -Lavatory -(MPC 701) Install the waste piping to code.
22. First Floor -Lavatory -(MPC .0100 P & Q & 419.2) Install the water piping to code.
23. First Floor -Sink -(MPC .0100 E & 901) Install a proper fixture vent to code.
24. First Floor -Sink -(MPC 701) Install the waste piping to code.
25. First Floor -Toilet Facilities -(MPC 301.1) Repair/replace the fixture that is missing, broken or has parts missing.
26. First Floor -Toilet Facilities -(MPC 402.6) Install a proper flanged fixture connection on a firm base.
27. First Floor -Tub and Shower -(MPC 408.3) Install scald and thermal shock protection, ASSE Standard 1016.
28. First Floor -Tub and Shower -(MPC 409.4) Install a hot water temperature limiting device, ASSE Standard 1070.
29. First Floor -Tub and Shower -(MPC 417.1) Provide a code compliant faucet with the proper air gap.
30. Second Floor -Gas Piping -(MFGC 411) Install an approved shut off; connector and gas piping for the range.
31. Second Floor -Lavatory -(MPC .0100 E & 901) Install a proper fixture vent to code.
32. Second Floor -Lavatory -(MPC 701) Install the waste piping to code.
33. Second Floor -Lavatory -(MPC .0100 P & Q & 419.2) Install the water piping to code.
34. Second Floor -Toilet Facilities -(MPC 402.6) Install a proper flanged fixture connection on a firm base.
35. Second Floor -Tub and Shower -(MPC 301.1) Repair/replace the faucet that is missing, broken or has parts missing.
36. Second Floor -Tub and Shower -(MPC 409.2) Provide an approved waste stopper
37. Second Floor -Tub and Shower -(MPC 417.1) Provide a code compliant faucet with the proper air gap.
38. All the above corrections to waste, vent, water, and gas piping shall be per the Minnesota Plumbing Code Chapter 4714, Minnesota Rules Chapter 326, 4716, 1300, the Minnesota Mechanical Code, the Minnesota Fuel Gas Code, and Saint Paul Regional Water Services Water Code. All plumbing must be done by a plumbing contractor licensed in the State of Minnesota and the City of St. Paul by a plumber licensed in the State of Minnesota who also possess a City of Saint Paul Competency Card and after obtaining an approved City of Saint Paul Plumbing Permit.

**Heating Inspector: Erik Witt**

**Phone: 651 -266 -9045**

---

1. Install approved level handle manual gas shutoff valve on furnace/boiler and remove unapproved valve.
2. Clean and Orsat test furnace/boiler burner. Check all controls for proper

operation. Check furnace heat exchanger for leak; provide documentation from a licensed contractor that the heating unit is safe.

3. Install approved metal chimney liner.
4. Replace furnace/boiler flue venting to code.
5. Vent clothes dryer to code.
6. Provide adequate combustion air and support duct to code.
7. Provide support for gas lines to code.
8. Plug, cap and/or remove all disconnected gas lines.
9. Provide heat in every habitable room and bathrooms.
10. Support supply and return piping from heating system according to code.
11. Conduct witnessed pressure test on hot water heating system and check for leaks.
12. Repair or replace fin tube radiation and covers as needed.
13. Mechanical permits are required for the above work.

**Notes:**

---

1. See attachment for permit requirements and appeals procedure.

**This is a registered vacant building. In order to sell or reoccupy this building, all deficiencies listed on this code compliance report must be corrected in accordance with the Minimum Housing Standards of the St. Paul Legislative Code (Chapter 34) and all required permits must receive final approval within six (6) months of the date of this report. One (1) six-month time extension may be requested by the owner and will be considered if it can be shown that the code compliance work is proceeding and is more than fifty (50) percent complete in accordance with Legislative Code Section 33.03(f).**

You may file an appeal to this notice by contacting the City Clerk's Office at 651-266-8688. Any appeal must be made in writing within 10 days of this notice. (You must submit a copy of this notice when you appeal, and pay a filing fee.)

Re: 331 Lawson Ave W  
July 30, 2021  
Page 7

If you have any questions regarding this inspection report, please contact Nathan Bruhn between 7:30 - 9:00 AM at 651-266-9033 or leave a voice mail message.

Sincerely,

Nathan Bruhn  
Code Compliance Officer  
Department of Safety and Inspections  
City of Saint Paul  
375 Jackson Street, Suite 220  
Saint Paul MN 55101  
Phone: 651-266-9033  
Email: [nathan.bruhn@ci.stpaul.mn.us](mailto:nathan.bruhn@ci.stpaul.mn.us)

Attachments