



CITY OF SAINT PAUL

OFFICE OF THE CITY COUNCIL

310 CITY HALL

15 WEST KELLOGG BOULEVARD

SAINT PAUL, MN 55102-1615

EMAIL: legislativehearings@ci.stpaul.mn.us

PHONE: (651) 266-8560 FAX: (651) 266-8574

May 25, 2012

Molly McGrane
Window World
2211 11th Ave Ste 130
North St Paul MN 55109

VIA EMAIL: mollym@windowworldmn.com

Re: Appeal for property at 1260 Grotto Street North

Dear Ms. McGrane:

This is to confirm that Marcia Moermond, Legislative Hearing Officer, has reviewed the above-referenced matter and recommended that the City Council grant a 4-inch variance on the openable height of three double hung replacement egress bedroom windows measuring 20 inches high by 23.21 inches wide.

This matter will be on the City Council Public Hearing on Wednesday, June 20, 2012 at 5:30 p.m. in Room 300 Council Chambers; however, since the appeal has been granted you don't need to appear.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

MV

Mai Vang
Legislative Hearing Coordinator

c: Jim Bloom (email)
Stephen Ubl (email)