

APPLICATION FOR APPEAL

Saint Paul City Council – Legislative Hearings

RECEIVED

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8585

AUG 03 2020

CITY OF EDK

DATE & TIME Legislative Hearing Office) Legislative Hearing Office) Legislative Hearing Office) Legislative Hearing Office) Legislative Hearing Hearing: Lity Hall/Courthouse Legislative Hearing: Legislative Hearing Office) Legislative Hearing Legislative Hearing Office) Legislative Hearing Legislative Hearing Office) Legislative Hearing
4 1:00 p.m.
State: MN Zip: 55107
Drbkcapital.com
O7/20/2020
Cell
ents Are Acceptable Blow 353-8543

Ricardo X. Cervantes, Director

SAINT

CITY OF SAINT PAUL

375 Jackson Street, Suite 220 St Paul, Minnesota 55101-1806

 Telephone:
 651-266-8989

 Facsimile:
 651-266-9124

 Web:
 www.stpaul.gov/dsi

July 22, 2020 CAROLYN BROWN COMMUNITY STABILIZATION PROJECT 501 DALE STREET N SUITE 203 SAINT PAUL MN 55103

Revocation of Fire Certificate of Occupancy and Order to Vacate

RE:

1017 REANEY AVE

Ref. # 111125

Dear Property Representative:

Your building was inspected on July 22, 2020, for the renewal of the Certificate of Occupancy. Since you have failed to comply with the applicable requirements, it has become necessary to revoke the Certificate of Occupancy in accordance with Section 40.06 of the Saint Paul Legislative Code. A reinspection will be made on August 7, 2020 at 2:00P.M. or the property vacated.

The Saint Paul Legislative Code further provides that no building shall be occupied without a Certificate of Occupancy. Failure to immediately complete the following deficiency list or the building vacated may result in a criminal citation.

DEFICIENCY LIST

- 1. SPLC 34.11 (6), 34.35 (3) Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.-
- 2. SPLC 39.02(c) Complete and sign the smoke detector affidavit and return it to this office.
- 3. SPLC 34.19 Provide access to the inspector to all areas of the building.-

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: http://www.stpaul.gov/cofo

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse,

An Equal Opportunity Employer

15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas Fire Safety Inspector

Ref. # 111125