



CITY OF SAINT PAUL  
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220  
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989  
Facsimile: 651-266-8951  
Web: [www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)

December 9, 2016

SHAMROCKS BAR C/O TED CASPER  
995 SEVENTH ST W  
SAINT PAUL MN 55102

RE: RE-INSPECTION FIRE CERTIFICATE OF OCCUPANCY WITH DEFICIENCIES  
995 7TH ST W  
Ref. # 12215

Dear Property Representative:

Your building was re-inspected for the Fire Certificate of Occupancy on September 8, 2016. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected immediately.

***A re-inspection will be made on or after December 20, 2016.***

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

#### DEFICIENCY LIST

1. 995 KITCHEN BASEMENT OPENING - MSFC 703.1 - Provide and maintain fire rated wall construction with approved materials and methods. This work may require a permit(s). Call DSI at (651) 266-8989. The minimum rating must be: 1 HOUR
2. 995 STAGE LIGHTS - MSFC 605.5 - Discontinue use of extension cords used in lieu of permanent wiring.  
*-Remove extension cords from lights.*
3. CORK ROOM - MSFC 1010.1, 1003.3.1.2 - Exit doors must swing in the direction of travel. Change the swing of the door.  
*-Remove chairs in excess of 41 or provide two proper exits from room.*

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at [kris.skow-fiske@ci.stpaul.mn.us](mailto:kris.skow-fiske@ci.stpaul.mn.us) or call me at 651-266-8949 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Kris Skow-Fiske  
Fire Inspector  
Ref. # 12215