



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

RECEIVED

JUN 23 2011

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number Cash)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:

Tuesday, 6-28-11

Time 1:30

Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1402 WOODBRIDGE ST. City: ST. PAUL State: MN Zip: 55117

Appellant/Applicant: CHAMPION WINDOWS OF MPLS. Email: MINNEAPOLIS.RWMC@CHAMPIONFACTORYDIRECT.COM

Phone Numbers: Business 763-514-2054 Residence _____ Cell 763-226-1356

Signature: Ken Anderson Date: JUNE 23, 2011

Name of Owner (if other than Appellant): LOU HER

Address (if not Appellant's): 1402 WOODBRIDGE ST. ST. PAUL MN 55117

Phone Numbers: Business _____ Residence 651-487-1746 Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

SEE ATTACHMENT

March 14, 2011

To: City of St. Paul
From: Champion Window Company of Minneapolis
Subject: Lou Her Window Replacement, 1402 Woodbridge St

The permit submitted for this project includes three bedrooms that will not meet the full requirements of St. Paul Egress code. This egress window will meet all criteria except for the 24" minimum clear opening. The clear opening height of these windows will be approximately 15.625".

Specifications of new window:

Net clear opening width: 26.1/2"
Net clear opening height: 15.5/8"
Total Glazing Area: Approximately 9.9 square feet
Distance floor to sill: Less than 44"

Please accept this proposal to avoid excessive cost to the homeowner. Total cost of enlarging the openings for this window may exceed \$1000 additional cost, depending on possible electrical wiring charges.

Scott Pierson

Champion Window Company



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: June 23, 2011

APPEAL PROPERTY ADDRESS: 1402 WOODBRIDGE ST

APPLICANT NAME: CHAMPION WINDOW COMPANY OF MINNEAPOLS
LLC

PHONE NUMBER: 763-574-2054

PERMIT NUMBER: 11 115843

TYPE OF WINDOW DOUBLE HUNG

NUMBER OF WINDOWS 3

| | | | |
|---|---------|---|--------|
| Total Glazed Area Minimum 5 Square Feet | 9.9 | Difference from Required Area | +4.9 |
| Width of Opening Minimum 20 Inches | 26.5" | Difference from Required Opening | +6.5" |
| Height of Opening Minimum 24 Inches | 15.625" | Difference from Required Opening | -4.375 |
| Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings | 44 | Difference from Maximum Height | -4 |

COMMENTS: THE NON COMPLIANCE INFORMATION WAS PROVIDED PRIOR TO THE PERMIT ISSUANCE. PERMIT WAS ISSUED IN ERROR. NO WORK HAS STARTED ON PROPERTY.

Reviewed by: BLOOM