



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

RECEIVED

APR 17 2011

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 4/26/11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 2157 Temple Ct City: St Paul State: MN Zip: 55104

Appellant/Applicant: Evika Hanson Email erika.d.hanson@gmail.com

Phone Numbers: Business 612-316-0894 Residence N/A Cell 612-384-7417

Signature: [Signature] Date: 4-1-11

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

See attached letter



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: February 7, 2011

Enika Hanson

APPEAL PROPERTY ADDRESS: 2157 TEMPLE COURT

APPLICANT NAME: FBC CONCEPTS

PHONE NUMBER: 651-266-9023

PERMIT NUMBER: 10 938094

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 3

Total Glazed Area Minimum 5 Square Feet	1184 sq. inches	Difference from Required Area	+363 sq. inches
Width of Opening Minimum 20 Inches	28.5 inches	Difference from Required Opening	+8.5 inches
Height of Opening Minimum 24 Inches	12 inches	Difference from Required Opening	- 12 inches
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	43.5 inches	Difference from Maximum Height	+4.5 inches

COMMENTS:

Reviewed by: Virgil Thomas

April 7, 2011

Saint Paul City Clerk
310 City Hall
15 W Kellogg Blvd
Saint Paul, MN 55102

To Whom It May Concern:

During December 2010 I had replacement, vinyl windows installed at my primary residence by FBC Concepts (permit number 10-938094). The frame of the window was not altered; the replacement windows replaced the original, 60+ year windows. Now, all the windows open.

It wasn't until Virgil Thomas visited my home for an inspection (the contractor was not present) that I learned that my bedroom windows were not "up to code." As you can see from the Egress Window Non-Compliance Determination form included with this letter that I have 3 windows not in compliance. Being the windows are already installed, I'm requesting your approval for variance.

Thank you for your consideration.

Regards,

A handwritten signature in cursive script, appearing to read "Erika Hanson".

Erika Hanson
2157 Temple Court
Saint Paul, MN 55104
612-384-7417