



APPLICATION FOR APPEAL

RECEIVED
AUG 17 2011
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:

Tuesday, 8-23-11

Time 1:30

Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 980 Conway Ave City: St. Paul State: MN Zip: 55106

Appellant/Applicant: BEE VUE Email vueproperties@comcast.net

Phone Numbers: Business 651-338-5377 Residence _____ Cell 651-338-5377

Signature: [Handwritten Signature] Date: _____

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

Ceiling height on bathroom



CITY OF SAINT PAUL

Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Telephone: 651-266-8989
Saint Paul, MN 55101-1806 Fax: 651-266-8951

August 10, 2011

BEE VUE
21301 FURMAN ST NE
WYOMING MN 55092-9626

CORRECTION NOTICE - RE-INSPECTION COMPLAINT

RE: 980 CONWAY ST
Ref. # 107745

Dear Property Representative:

A re-inspection was made on your building on August 10, 2011, in response to a referral. You are hereby notified that the following deficiencies must be corrected immediately. A reinspection will be made on or after September 9, 2011.

Failure to comply may result in a criminal citation or the revocation of the Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

DEFICIENCY LIST

1. UNIT 2 - SPLC 34.13 (1) - Provide and maintain all habitable areas with a ceiling height of 7 feet over 1/2 the floor area.-BATHROOM CEILING HEIGHT= 7 FOOT AREA MEASURES 78INCHES BY 30 INCHES. TOTAL MEASURE MENT OF ROOM IS 8 FEET BY 14 FEET. KNEEWALL IS 45 INCH IN HEIGHT.

For an explanation or information on some of the violations contained in this report, please visit our web page at: <http://www.ci.stpaul.mn.us/index.aspx?NID=211>

If you have any questions, email me at pat.fish@ci.stpaul.mn.us or call me at 651-266-8942 between 7:30 a.m - 9:00 a.m.

Please help to make Saint Paul a safer city in which to live and work.

Sincerely,

Pat Fish
Fire Inspector