



APPLICATION FOR APPEAL

RECEIVED
APR 25 2011
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

Date and Time of Hearing:
 Tuesday, 5-10-11
 Time 1:30
Location of Hearing:
 Room 330 City Hall/Courthouse

Appellant/Applicant: Kerrin Knudsen

Address: 1489 Matilda City: St. Paul State: MN Zip: _____

Phone Numbers: Business _____ Residence _____ Cellular 6125785294

Signature: [Handwritten Signature] Date: 4-26-11

Name of Owner (if other than Appellant): _____

Address: _____ City: _____ State: _____ Zip: _____

Phone Numbers: Business _____ Residence _____ Cellular _____

State specifically what is being appealed and why (use an attachment if necessary):

inspector review windows o.k. ✓

NOTE: Any person unsatisfied by the final decision of the City Council may obtain judicial review by timely filing an action as provided by law in District Court or Court of Appeals

Fee Received: _____ Receipt Number: _____



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 5.10.10

APPEAL PROPERTY ADDRESS: 1489 Mato/dg

APPLICANT NAME: _____ PHONE NUMBER: _____

PERMIT NUMBER: _____

TYPE OF WINDOW: Double Hung

NUMBER OF WINDOWS: 2

	<u>main level North</u>	<u>upper level North</u>	<u>upper level Southwest</u>	
TOTAL GLAZED AREA:	<u>7.7</u>	<u>10.6</u>	<u>6.2</u>	DIFFERENCE FROM REQUIRED AREA: <u>+2.7</u> <u>+1.0</u> <u>+1.2</u> sq. ft
WIDTH OF OPENING:	<u>29"</u>	<u>30.5"</u>	<u>30.5"</u>	DIFFERENCE FROM REQUIRED OPENING: <u>+9"</u> <u>+6.5"</u> <u>+10.5"</u>
HEIGHT OF OPENING:	<u>20"</u>	<u>30"</u>	<u>16"</u>	DIFFERENCE FROM REQUIRED OPENING: <u>-4"</u> <u>-7"</u> <u>-8"</u>
HEIGHT OF OPENING TO FINISHED FLOOR:	<u>35"</u>	<u>26.5"</u>	<u>40"</u>	DIFFERENCE FROM MAXIMUM HEIGHT: <u>-13"</u> <u>-2.5"</u> <u>-8"</u>

COMMENTS: Recommend approval

FROM: Ben Eggers