



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

No. 0443 P. 10

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 4-24

APPEAL PROPERTY ADDRESS: 1688 HYACINTH

APPLICANT NAME: PUBLIC HEALTH (DANIEL) PHONE NUMBER: 266-1143
SCHMIDT

PERMIT NUMBER: _____

TYPE OF WINDOW: DOUBLE HUNG

NUMBER OF WINDOWS: 2

TOTAL GLAZED AREA: 9.1 sq ft DIFFERENCE FROM REQUIRED AREA: COMP

WIDTH OF OPENING: 25.3" DIFFERENCE FROM REQUIRED OPENING: COMP

HEIGHT OF OPENING: 19.9" DIFFERENCE FROM REQUIRED OPENING: 4.1"

HEIGHT OF OPENING
TO FINISHED FLOOR: 248" DIFFERENCE FROM MAXIMUM HEIGHT: COMP

RECOMMENDATION (IF APPLICABLE): _____

RECEIVED

APR 24 2012

CITY CLERK

FROM: _____

Apr. 24. 2012 1:17PM

No. 0443 P. 11

Apr. 24. 2012 1:17PM St Paul-Ramsey Co. Public Health

Select a Model	
(Model 0201)	0201
Excalibur Double Hung	
Top Sash Width	26.5000
Top Sash Height	25.1250
Bottom Sash Width	27.5000
Bottom Sash Height	26.1250
Top Glass Width	24.8125
Top Glass Height	23.4375
Bottom Glass Width	25.8125
Bottom Glass Height	24.4375
Screen Width	26.0625
Screen Height	60.6000
Top Sash Weight (Plus 5 lb)	21 lb
Top Balance Size (C.F.)	54BU
Top Balance Size (Spiral)	21-7B
Bottom Sash Weight	17 lb
Bottom Balance Size (C.F.)	54AT
Bottom Balance Size (Spiral)	25-6R
Egress Opening Width	18.3449
Egress Opening Height	18.9375
Egress Opening Area (sq.ft.)	3.5090

Min. W: 11	Max. W: 62
Min. H: 20	Max. H: 64
Max. U/I: 132	

Width:	29.75	Exact Size	29.75
Height:	53.375	Exact Size	53.375

Extrusion: Select Extrusion

Opening: Board Size

Type: Standard

Screen: Full

Glass: Double Strength (3 req)

AC Sash Calculator

1687 HYACINTH