



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

No. 0443 P. 8

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 4-24-12

APPEAL PROPERTY ADDRESS: 1081 STINSON

APPLICANT NAME: PUBLIC HEALTH (DANIEL SCHMIDT) PHONE NUMBER: 266-1143

PERMIT NUMBER: _____

TYPE OF WINDOW: DH

NUMBER OF WINDOWS: 2

TOTAL GLAZED AREA: 9.0 ft²

DIFFERENCE FROM REQUIRED AREA: COMP

WIDTH OF OPENING: 23.1"

DIFFERENCE FROM REQUIRED OPENING: COMP

HEIGHT OF OPENING: 21.9"

DIFFERENCE FROM REQUIRED OPENING: 3.1"

HEIGHT OF OPENING
TO FINISHED FLOOR: 48"

DIFFERENCE FROM MAXIMUM HEIGHT: COMP

RECOMMENDATION (IF APPLICABLE):

RECEIVED

APR 24 2012

CITY CLERK

Apr. 24, 2012 1:16 PM

FROM: _____

No. 0443 P. 9

St Paul-Ramsey Co. Public Health

Apr. 24. 2012 1:17PM

Select a Model		Min. W: 11	Max. W: 52
(Model 0201) Excaltibur Double Hung		Min. H: 20	Max. H: 34
			Max. U: 132
Top Sash Width	34.3750	Exact Size	
Top Sash Height	27.1250	Width: 27.625	27.625
Bottom Sash Width	26.3750	Height: 57.325	57.525
Bottom Sash Height	28.0750	Extrusion: Select Extrusion << For Arch-Top Models Only	
Top Glass Width	21.6875	Opening: Exact Size	
Top Glass Height	25.4375	Type: Standard	
Bottom Glass Width	23.6875	Screen: Full	
Bottom Glass Height	28.3750	Glass: Double Strength (3 mm)	
Screen Width	23.9375	<input type="checkbox"/> AC Sash Calculator	
Screen Height	54.4375		
Top Sash Weight (Plus 5 lb)	21 lb		
Top Balance Size (C.F)	68BU		
Top Balance Size (Spiral)	23-8R		
Bottom Sash Weight	17 lb		
Bottom Balance Size (C.F)	5NAT		
Bottom Balance Size (Spiral)	27-7R		
Egress Opening Width	23.2150		
Egress Opening Height	21.9375		
Egress Opening Area (sq.ft.)	3.6370		

1081 STINSON