

RECEIVED
FEB 24 2011
CITY CLERK

3/15/11
@ 1:30

Saint Paul - Ramsey County Department of Public Health
Environmental Health Section
2785 White Bear Avenue North Suite 350
Maplewood, MN 55109-1320
FAX: (651) 266-1177

Date: 2-24-11

To FAX#: 6-8574

FACSIMILE TRANSMISSION
Cover Sheet and Transmittal Form

To: Mai Yang, Paralegal

Location: Legislative Hearing Office
City of St. Paul

Sender: Daniel Schmidt / Tim Hannareddy
St. Paul - Ramsey Cty. Dept. of Public Health

This transmission consists of _____ pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1173 (DANIEL SCHMIDT)


Message:

Request for Egress Window Non-Compliance Determination

Attachments: Egress Window Non-Compliance Determination Form

CONFIDENTIALITY NOTICE

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.





CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KEILLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 2/24/11

APPEAL PROPERTY ADDRESS: 1147 MAGNOLIA
APPLICANT NAME: POLK HEATH - DANIEL PHONE NUMBER: 651-266-1143

PERMIT NUMBER: _____
TYPE OF WINDOW: DH
NUMBER OF WINDOWS: 2

TOTAL GLAZED AREA: 8.4 sqft DIFFERENCE FROM REQUIRED AREA: COMPLIES
WIDTH OF OPENING: 23.2" DIFFERENCE FROM REQUIRED OPENING: COMPLIES
HEIGHT OF OPENING: 20.06 DIFFERENCE FROM REQUIRED OPENING: 3.94"
HEIGHT OF OPENING TO FINISHED FLOOR: 48" DIFFERENCE FROM MAXIMUM HEIGHT: COMPLIES

RECOMMENDATION (IF APPLICABLE): SEE EXHIBIT A

FROM: _____

EXHIBIT A

Select a Model		Min. W: 11	Max. W: 52
: 001		Min. H: 10	Max. H: 64
(Model 0201)		Max. U/I: 132	
Excaltibur Double Hung			
Top Sash Width	24.3750	Exact Size	
Top Sash Height	25.2500	Width: 27.625	27.625
Bottom Sash Width	25.7500	Height: 53.625	53.625
Bottom Sash Height	25.2500		
Top Glass Width	22.8750		
Top Glass Height	23.5625		
Bottom Glass Width	23.8750		
Bottom Glass Height	24.6250		
Screen Width	21.8750		
Screen Height	50.7500		
Top Sash Weight (Plus 4 lb)	20 lb		
Top Balance Size (C/F)	56R0		
Top Balance Size (Serial)	24.7B		
Bottom Sash Weight	16 lb		
Bottom Balance Size (C/F)	8L0		
Bottom Balance Size (Serial)	25-6R		
Frame Opening Width	23.2190		
Frame Opening Height	20.6825		
Frame Opening Area (sq.ft)	3.2350		

23.9 x 50.7 = 1211 ÷ 144 = 8.4 sq ft