

Saint Paul - Ramsey County Department of Public Health
Environmental Health Section
2785 White Bear Avenue North Suite 350
Maplewood, MN 55109-1320
FAX: (651) 266-1177

Date: 5-17-11 4:30

FACSIMILE TRANSMISSION
Cover Sheet and Transmittal Form

To/FAX#: 6-8574

RECEIVED
APR 28 2011
CITY CLERK

To:	<u>Mai Yang Paralegal</u>
Location:	<u>Legislative Hearing Office</u> <u>City of St. Paul</u>
Sender:	<u>Daniel Schmidt / Tim Hanorelly</u> <u>St. Paul-Ramsey Cty. Dept. of Public Health</u>

This transmission consists of 3 pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1143 (DANIEL SCHMIDT)

Message:

Request for Egress Window Non-Compliance Determination
Attachments: Egress Window Non-Compliance Determination Form

CONFIDENTIALITY NOTICE

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

No. 7343
TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102
PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 4-28-11

APPEAL PROPERTY ADDRESS: 646 Van Buren

APPLICANT NAME: Public Health - David PHONE NUMBER: 651-266-1143

PERMIT NUMBER: _____

TYPE OF WINDOW: Double Hung

NUMBER OF WINDOWS: 3

TOTAL GLAZED AREA: 8.7 sq ft DIFFERENCE FROM REQUIRED AREA: COMPLEES

WIDTH OF OPENING: 24.2" DIFFERENCE FROM REQUIRED OPENING: COMPLEES

EIGHT OF OPENING: 19.93" DIFFERENCE FROM REQUIRED OPENING: 4.07"

EIGHT OF OPENING: 4.48" DIFFERENCE FROM MAXIMUM HEIGHT: COMPLEES

St Paul-Ramsey Co. Public Health

RECOMMENDATION (IF APPLICABLE): SEE EXHIBIT A

2:38PM

Apr. 28. 2011
FROM: _____




EXHIBIT A

Select a Model

(Model 0201) 000

Excabur Double Hung

Top Sash Width	28.3750
Top Sash Height	28.4250
Bottom Sash Width	28.3750
Bottom Sash Height	28.1250
Top Glass Width	23.4375
Top Glass Height	24.4375
Bottom Glass Width	24.4375
Bottom Glass Height	24.8075
Screen Width	40.6000
Screen Height	20.10
Top Sash Weight (Pax 5 lb)	5980
Top Sash Weight (C/F)	21.73
Top Balance Size (S/S)	17 lb
Bottom Sash Weight	5960
Bottom Balance Size (C/F)	24.2190
Bottom Balance Size (S/S)	14.8975
Egress Opening Width	3.3500
Egress Opening Area (sq ft)	

Min. W: 11 Max. W: 52
Min. H: 20 Max. H: 34 Max. Lx: 132

Width: 28.625 28.625
Height: 53.375 53.375

Exhaust: Sash Exhaust
Opening: Exhaust Size
Type: Standard
Screen: 14
Glass: Insulate Strength (3 mm)

For Arch Top Models Only

☐ HC Sash Overlapper

$$24.9 \times 50.6 = 1257 \div 144 = 8.7 \text{ sq ft}$$