



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street., Suite 220
Saint Paul, MN 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-1919
Web: www.stpaul.gov/dsi

331

August 27, 2012

10-911503

RV Holdings Five LLC
1112 Price Ave
Columbia SC 29201

Trinidad Garcia
930 Dodd Road
St Paul MN 55118

Order to Abate Nuisance Building(s)

Dear Sir or Madam:

The Vacant/Nuisance Buildings Unit, Department of the Department of Safety and Inspections, Division of Code Enforcement, hereby declares the premises located at:

1009 WHITE BEAR AVE N

With the following Historic Preservation information: NONE

and legally described as follows, to wit:

Hazel Park Lots 4 Thru Lot 6 Blk 2

to comprise a nuisance condition in violation of the Saint Paul Legislative Code, Chapter 45.02, and subject to demolition under authority of Chapter 45.11.

On August 21, 2012 a Building Deficiency Inspection Report was compiled and the following conditions were observed.

This list of deficiencies is not necessarily all the deficiencies present at this time. This building(s) is subject to the restrictions of Saint Paul Ordinance Chapter 33.03 and shall not again be used for occupancy until such time as a Certificate of Compliance or a Certificate of Occupancy has been issued. All repairs must be in accordance with appropriate codes. Changes or additions to the electrical system, mechanical system, or the plumbing system may necessitate updating or upgrading the systems involved.

This is a two-story, wood frame, single-family dwelling with a two-stall, wood frame detached garage.

The following Deficiency List is excerpted from the April 6, 2012 Code Compliance Report.

BUILDING

- Dry out basement and eliminate source of moisture.
- Remove mold, mildew and moldy or water damaged materials.
- Install handrails (34 inches - 38 inches above each nosing) and guardrails (36 inch minimum) at all stairways, and return hand rail ends into a newel post or wall per attachment.
- Repair or Replace any deteriorated window sash, broken glass, sash holders, re-putty, etc as necessary.
- Provide complete storms and screens, in good repair for all door and window openings.
- Provide functional hardware at all doors and windows
- Exit doors shall be capable of being opened from the inside, easily and without the use of a key. Remove all surface bolts.
- Repair or replace damaged doors and frames as necessary, including storm doors.
- Weather seal exterior doors, threshold and weather-stripping.
- Install floor covering in bathroom and kitchen that is impervious to water.
- Repair walls, ceiling and floors throughout, as necessary.
- Air-seal and insulate attic/access door.
- Provide major clean-up of premises.
- Prepare and paint interior and exterior as necessary. Observe necessary abatement procedures (EPA, MPCA and St. Paul Legislative Code, Chapter 34 for additional information) if lead base paint is present.
- Any framing members that required repair or do not meet code (where wall and ceiling covering is removed, members that are over-spanned, over-spaced, not being carried properly, door and window openings that are not adequately supported, etc.) are to be reconstructed in an approved manner.
- Install Smoke Detectors/Carbon Monoxide Detectors per MN Conservation Code and the MN Dept. of Labor and Industry: Install per code where feasible.
- Repair siding, soffit, fascia, trim, etc. as necessary.
- Provide proper drainage around house to direct water away from foundation of house.
- Provide proper drainage around house to direct water away from foundation of garage.
- Install rain leaders to direct drainage away from foundation.
- Provide general rehabilitation of garage.
- Install address numbers visible from street and on the alley side of garage.
- Provide durable, dustless parking surface as specified in the zoning code.
- Provide ground cover capable of controlling sediment and erosion.
- Review all applicable codes & policies when replacing windows including egress windows for sleeping rooms.
- Openings in stair risers must be less than 4 inches.
- Grade must drain away from foundation of dwelling. Maintain 6 inch clearance between wood and soil.
- Remove wall and rafters on north side of property.
- Repair siding around front door to code.
- Install new bottom panel on garage door.
- Install siding on garage to code.

- Install guardrail and handrail on basement stairs.
- Install tempered glass in window on stair landing.
- Install tempered glass in window over bathtub.
- Clean out gutters and repair or replace as needed.
- A building permit is required to correct the above deficiencies.

ELECTRICAL

- Provide a complete circuit directory at service panel indicating location and use of all circuits
- Verify a separate 20 ampere laundry circuit and a separate 20 ampere kitchen appliance circuit
- Verify that fuse amperage matches wire size
- Close openings in service panel/junction boxes with knockout seals and/or junction box covers
- Properly strap cables and conduits in basement
- Install globe-type enclosed light fixture on all closet lights.
- Repair or Replace all broken, missing or loose light fixtures, switches and outlets, covers and plates
- Check all outlets for proper polarity and verify ground on 3-prong outlets
- Install hard-wired, battery backup smoke detector per bulletin 80-1 and other smoke detectors as required by the IRC. Also, Install carbon monoxide detector(s) within 10 feet of all bedrooms
- Remove and or/ re-wire all illegal, improper or hazardous wiring in basement/garage
- Install a listed dead front and cover on existing fuse panel.
- Based on repair list purchase a permit for 9 circuits.
- All added receptacles must be grounded, tamper-resistant and be on an Arc-Fault Circuit Interrupter-protected circuit.
- Any open walls or walls that are opened as part of this project must be wired to the standards of the current NEC.
- All buildings on the property must meet the St. Paul Property Maintenance Code (Bulletin 80-1).
- All electrical work must be done by a Minnesota-licensed electrical contractor under an electrical permit.

PLUMBING

- Basement - Water Heater - No gas shut off or gas piping incorrect (IFGC 402.1)
- Basement - Water Heater - T and P relief discharge piping incorrect (MPC 2210 Subp. 4)
- Basement - Water Heater - Water piping incorrect (MPC 1730 Subp. 1)
- Basement - Water Heater - gas venting incorrect (IFGC 503)
- Basement - Water Meter - service valves not functional or correct (MPC 1800 Subp 3,4)
- Basement - Water Piping - add appropriate hangers (MPC 1430 Subp. 4)
- Basement - Water Piping - provide water piping to all fixtures and appliances (MPC 1700)
- Basement - Water Piping - repair or replace all corroded, broken or leaking piping (MPC 4715.1720)

- Basement - Water Piping - run 1 inch water line from meter to first major take off (SPRWS Water Code)
- Basement - Soil and Waste Piping - unplug floor drain.
- Basement - Soil and Waste Piping - unplugged or open piping; back pitched piping (MPC 1000)
- Basement - Gas Piping - replace improper piping or fittings (IFGC 406.1.2)
- Basement - Laundry tub - clothes washer is incorrect.
- Basement - Laundry Tub - provide a vacuum breaker for the spout (MPC 2000 B)
- Basement - Laundry Tub - waste incorrect (MPC 2300)
- Basement - Lavatory - faucet is missing, broken, or parts missing (MPC 0200.P.)
- Basement - Lavatory - fixture is broken or parts missing (MPC 0200 O.)
- Basement - Lavatory - waste incorrect (MPC 2300)
- Basement - Lavatory - water piping incorrect (MPC 0200 P.)
- Basement - Soil and Waste Piping - improper connections, transitions, fittings or pipe usage (MPC 2420)
- Basement - Toilet Facilities - waste incorrect (MPC 2300) also reset toilet on firm base.
- Second Floor - Lavatory - waste incorrect (MPC 2300)
- Second Floor - Toilet Facilities - waste incorrect (MPC 2300) also reset toilet on firm base impervious to water.
- Second Floor - Tub and Shower - Provide access (MPC 0900)
- Second Floor - Tub and Shower - faucet is missing, broken or parts missing (MPC 0200. P.)
- Second Floor - Tub and Shower - provide anti-scald valve (MPC 1380. Subp. 5)
- Second Floor - Tub and Shower - provide stopper (MPC 1240)
- Second Floor - Tub and Shower - replace waste and overflow (MPC 1240)
- Exterior - Lawn Hydrants - Broken or parts missing (MPC 0200 K)
- Exterior - Lawn Hydrants - Requires backflow assembly or device (MPC 2000)
- Comments: - Need permits for all PEX water piping that was installed.
- Obtain plumbing permits prior to commencement of work.

HEATING

- Install approved lever handle manual building shutoff gas valve in an accessible location ahead of the first branch tee
- Provide support for gas lines to code
- Plug, cap and/or remove all disconnected gas lines and unapproved valves. Test entire gas piping system.
- Provide a window in the bathrooms with an aggregate glazing area of not less than 3 square feet, one-half of which must be openable or provide exhaust system vented to outside. A mechanical ventilation permit is required if an exhaust system is installed.
- Mechanical gas and warm air permits are required for the above work.
- Install heating system to code.

As owner, agent or responsible party, you are hereby notified that if these deficiencies and the resulting nuisance condition is not corrected by **September 26, 2012** the Department of Safety and Inspections, Division of Code Enforcement, will begin a substantial abatement process to

demolish and remove the building(s). The costs of this action, including administrative costs and demolition costs will be assessed against the property taxes as a special assessment in accordance with law.

As first remedial action, a Code Compliance Inspection Report must be obtained from the Building Inspection and Design Section, 375 Jackson Street, Suite 220, (651) 266-8989. This inspection will identify specific defects, necessary repairs and legal requirements to correct this nuisance condition. You may also be required to post a five thousand dollar (\$5,000.00) performance bond with the Department of Safety and Inspections before any permits are issued, except for a demolition permit. Call the Department of Safety and Inspections for more information at 651-266-8989.

If this building is located in a historic district or site (noted on page 1, above, just below the property address) then you must contact Heritage Preservation (HPC) staff to discuss your proposal for the repairs required by this order and compliance with preservation guidelines. Copies of the guidelines and design review application and forms are available from the Department of Safety and Inspections web site (see letterhead) and from the HPC staff. No permits will be issued without HPC review and approval. HPC staff also can be reached by calling 651-266-9078.

As an owner or responsible party, you are required by law to provide full and complete disclosure of this "Order to Abate" to all interested parties, all present or subsequent renters and any subsequent owners. The property shall not be sold, transferred or conveyed in any manner until the Nuisance Conditions have been abated and the Certificate of Code Compliance or Certificate of Occupancy has been issued.

The Enforcement Officer is required by law to post a placard on this property which declares it to be a "nuisance condition", subject to demolition and removal by the City. This placard shall not be removed without the written authority of the Department of Safety and Inspections, Division of Code Enforcement. The department is further required to file a copy of this "Order to Abate" with the City Clerk's Office.

If corrective action is not taken within the time specified in this order, the Enforcement Officer will notify the City Council that abatement action is necessary. The City Clerk will then schedule dates for Public Hearings before the City Council at which time testimony will be heard from interested parties. After this hearing the City Council will adopt a resolution stating what action if any, it deems appropriate.

If the resolution calls for abatement action the Council may either order the City to take the abatement action or fix a time within which this nuisance must be abated in accordance with the provisions of Chapter 33 of the Saint Paul Legislative Code and provide that if corrective action is not taken within the specified time, the City shall abate this nuisance. The costs of this action, including administrative costs will be assessed against the property as a special assessment in accordance with law.

August 27, 2012
1009 WHITE BEAR AVE N
page 6

If you have any questions or request additional information please contact **Rich Singerhouse** between the hours of 8:00 and 9:30 a.m. at **651-266-1945**, or you may leave a voice mail message.

Sincerely,

Rich Singerhouse
Vacant Buildings Enforcement Inspector

cc: Legistar Approval list and City Council

ota60135 5/11