



# APPLICATION FOR APPEAL

**Saint Paul City Clerk**

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

RECEIVED

MAY 09 2011

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 5-17-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

WORK-17

## Address Being Appealed:

Number & Street: 1896 Grand Ave City: St Paul State: MN Zip: \_\_\_\_\_

Appellant/Applicant: Dana Verdeja Email Dana.Verdeja@Activision.COM

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell 651 235 4678

Signature: [Signature] Date: 5/16/11

Name of Owner (if other than Appellant): \_\_\_\_\_

Address (if not Appellant's): 4735 Kent St Shoreview MN 55126

Phone Numbers: Business \_\_\_\_\_ Residence 651 463 0958 Cell \_\_\_\_\_

## What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

---

---

---

---

---


---

---

---

---

---



CITY OF SAINT PAUL  
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220  
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989  
Facsimile: 651-266-8951  
Web: [www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)

May 2, 2011

DANALEX PARTNERS  
4735 KENT ST  
SHOREVIEW MN 55126-6036

RE: RE-INSPECTION FIRE CERTIFICATE OF OCCUPANCY WITH DEFICIENCIES  
1896 GRAND AVE

Dear Property Representative:

Your building was re-inspected for the Fire Certificate of Occupancy on May 2, 2011. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected immediately.

**A re-inspection will be made on May 31, 2011 at 11:00 AM.**

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

DEFICIENCY LIST

1. 1st Floor - North Bedroom - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.  
-Double hung egress window measured 16.5 inches height by 16.5 inches width openable space and has a glazed area of 4.9 square feet.

2. 1st Floor - South Bedroom - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.  
-Double hung egress window measured 16.5 inches height by 16.5 inches width openable space and has a glazed area of 4.9 square feet.

3. 2nd Floor - North Bedroom - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information. -Double hung egress window measured 20 inches height by 37 inches width openable space and has a glazed area of 10.7 square feet.

4. Basement - UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work will require a permit(s). Call DSI at (651) 266-8989. -Obtain approval under permit.

5. Exterior - NFPA-211, 9-2 - Have the chimneys, fireplaces, and vents inspected for soundness, freedom from deposits, and correct clearances. Cleaning, maintenance, and repairs shall be done if indicated by the inspection. -Repair and tuck point damaged chimney.

6. Garage - SPLC 34.09 (1) b,c, 34.32 (1) b,c - Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint. -Repair damaged siding in an approved manner. -Obtain approval under permit for demolished garage.

7. SPLC 40.04 (5) On or after April 30, 2009, The owner of a building used for residential occupancy who is applying for their FIRST Fire Certificate of Occupancy, must complete the Minnesota Crime Free Multi Housing training program or other landlord training program approved by the Fire Marshal. The training must have occurred within the last two years and the owner must submit a certificate of attendance or provide verification of enrollment in the next scheduled class to the Fire Inspection Division-DSI. This requirement shall not apply to an owner who has held a Fire Certificate of Occupancy on another residential property in Saint Paul prior to April 30, 2009. -Contact 651-266-5451 to enroll.

8. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.

For an explanation or information on some of the violations contained in this report, please visit our web page at: <http://www.ci.stpaul.mn.us/index.aspx?NID=211>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at [william.beumer@ci.stpaul.mn.us](mailto:william.beumer@ci.stpaul.mn.us) or call me at 651-266-8991 between 7:30 a.m - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

William Beumer  
Fire Inspector

one

Done

WAB  
Jan 2011