



APPLICATION FOR APPEAL

RECEIVED

AUG 16 2012

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which
are being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed
- ☐ Walk-In OR ☒ Mail-In

YOUR HEARING Date and Time:

Tuesday, Aug. 21

Time 1:30 P.M.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1453 Danforth St. City: St Paul State: Mn Zip: 55117

Appellant/Applicant: John Larson Email: LarsonJohn40@yahoo.com

Phone Numbers: Business — Residence — Cell 651-270-5239

Signature: John Larson Date: 8-13-12

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- ☐ Vacate Order/Condemnation/
Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☒ Fire C of O Deficiency List
- ☐ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other

#2, driveway parking area / year extension



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

August 8, 2012

JOHN LARSON JR
771 COTTAGE AVE W
ST PAUL MN 5517-4011

FIRE INSPECTION CORRECTION NOTICE

RE: 1453 DANFORTH ST
Ref. #105165
Residential Class: B

Dear Property Representative:

Your building was inspected on August 8, 2012 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

A re-inspection will be made on September 10, 2012 at 1:00pm.


9-14
Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. Basement - Laundry Room - UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work requires a permit(s). Call DSI at (651) 266-8989.-The dryer exhaust duct consists of flexible metal and flexible plastic ductwork held together with duct tape. This is not a code compliant dryer exhaust duct. Contact a licensed contractor to install a code compliant dryer exhaust duct. This work must be done under permit.

An Equal Opportunity Employer

- 
2. Exterior - Driveway and Parking Surface - SPLC 34.08 (7) - All parking spaces shall be paved with asphalt, concrete, or durable dustless surfacing. Before any existing spaces may be paved, site plan approval must be obtained as specified in the St. Paul Zoning Code. Contact DSI Zoning at 651-266-9090.-The driveway/parking space consists of gravel/class 5. This is not an approved driveway/parking surface. Install an approved driveway/parking surface.
 3. Garage - Garage Door Opener - MSFC 605.5 - Discontinue use of extension cords used in lieu of permanent wiring.-Remove and discontinue using the extension cord to supply power to the garage door opener. Garage door openers must be plugged directly into a permanently grounded outlet. Any newly installed outlet/wiring must be done by licensed electrical contractor under permit.
 4. Garage - SPLC 34.08 (5), 34.31 (3) - Repair, replace and maintain all exterior surfaces on fences, sheds, garages and other accessory structures free from holes and deterioration. Provide and maintain exterior unprotected surfaces painted or protected from the elements.-Repair/replace the soffits on the detached garage.
 5. Lower Unit - Southeast Bedroom - MSFC 1011.2 - Remove the materials that cause an exit obstruction. Maintain a clear and unobstructed exitway.-Remove the window A/C unit from the egress window.
 6. Lower Unit - Southeast Bedroom - MSFC 605.1- All light fixtures shall be maintained with protective globes if originally equipped.
 7. Lower Unit and Upper Unit - Laundry Room and Bedrooms - MN State Statute 299F.50 - Immediately provide and maintain an approved Carbon Monoxide Alarm in a location within ten (10) feet of each sleeping area. Installation shall be in accordance with manufacturer's instructions.-Replace the inoperable carbon monoxide detector in the basement laundry room. Install the required carbon monoxide detectors within 10 feet of the sleeping rooms.
 8. Upper Unit - Southeast Bedroom - SPLC 34.09 (3), 34.32 (3) - Repair and maintain the door in good condition.-Repair/replace the door than is not closing/latching.
 9. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
 10. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>.

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: wayne.spiering@ci.stpaul.mn.us or call me at 651-266-8993 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Wayne Spiering
Fire Inspector

Reference Number 105165