



APPLICATION FOR APPEAL

RECEIVED
OCT 31 2011
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:
Tuesday, <u>Nov-15, 2011</u>
Time <u>1:30 p.m.</u>
Location of Hearing:
<u>Room 330 City Hall/Courthouse</u>

walk in

Address Being Appealed:

Number & Street: 973 Watson City: St Paul State: MN Zip: 55102

Appellant/Applicant: The Window Store Home In Email Michelle@homesure inc.com

Phone Numbers: Business 612 353-5780 Residence _____ Cell 763-477-1820

Signature: Derek Lambert Date: 10-31-11

Name of Owner (if other than Appellant): Marty Marrone

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

needs to have a Double Hung window in up stairs for his Air Conditioning



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 31, 2011

APPEAL PROPERTY ADDRESS: 973 WATSON AVE

APPLICANT NAME: THE WINDOW STORE HOME IMPROVEMENTS INC

PHONE NUMBER: 612-353-5780

PERMIT NUMBER: 11 294200

TYPE OF WINDOW double hung

NUMBER OF WINDOWS 1

Total Glazed Area Minimum 5 Square Feet	6.44 sq. ft.	Difference from Required Area	+1.44 sq. ft.
Width of Opening Minimum 20 Inches	23.344"	Difference from Required Opening	+3.344
Height of Opening Minimum 24 Inches	15.875"	Difference from Required Opening	-4.125
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	Ok	Difference from Maximum Height	ok

COMMENTS:

Reviewed by: DD 10-31-11