

✓ Scanned



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

P. 4
No. 1083

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 6-6-12

APPEAL PROPERTY ADDRESS: 155 BAKER W.

APPLICANT NAME: PUBLIC HEALTH (DANIEL SCHMIDT) PHONE NUMBER: 651-266-1143

PERMIT NUMBER: _____

TYPE OF WINDOW: DOUBLE HUNG

NUMBER OF WINDOWS: 3

TOTAL GLAZED AREA: 10.6' sq DIFFERENCE FROM REQUIRED AREA: COMP

WIDTH OF OPENING: 27" DIFFERENCE FROM REQUIRED OPENING: COMP

HEIGHT OF OPENING: 22.06" DIFFERENCE FROM REQUIRED OPENING: 1.94"

HEIGHT OF OPENING ABOVE FINISHED FLOOR: < 48" DIFFERENCE FROM MAXIMUM HEIGHT: COMP

RECOMMENDATION (IF APPLICABLE):

Jun. 6. 2012 3:38PM

FROM: _____