

Saint Paul - Ramsey County Department of Public Health
 Environmental Health Section
 2785 Waite Bear Avenue North Suite 350
 Maplewood, MN 55109-1320
 FAX: (651) 266-1177

RECEIVED
 FEB 18 2011
 CITY CLERK

Date: 3-8-11 12:30

To FAX#: 6-8574

FACSIMILE TRANSMISSION
 Cover Sheet and Transmittal Form

To: Mai Yang Paralegal

Location: Legislative Hearing Office
City of St. Paul

Sender: Daniel Schmidt / Jim Yannarelli
St. Paul - Ramsey Cty. Dept. of Public Health

This transmission consists of _____ pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1143 (DANIEL SCHMIDT)

Message:

Request for Egress Window Non-Compliance Determination

Attachments: Egress Window Non-Compliance Determination Form

CONFIDENTIALITY NOTICE

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 2-18-11

APPEAL PROPERTY ADDRESS: 1137 JACKSON ST
APPLICANT NAME: Public Health - DANIEL HENRICH PHONE NUMBER: 651-266-1143
ON BEHALF OF ROSHAN SCHMIDT
RICE

PERMIT NUMBER: _____

TYPE OF WINDOW: PH


NUMBER OF WINDOWS: 1

TOTAL GLAZED AREA: 8.3 sq ft DIFFERENCE FROM REQUIRED AREA: COMPLIES
WIDTH OF OPENING: 23.3" DIFFERENCE FROM REQUIRED OPENING: COMPLIES
HEIGHT OF OPENING: 20.06" DIFFERENCE FROM REQUIRED OPENING: 3.94"
HEIGHT OF OPENING TO FINISHED FLOOR: 4' 48" DIFFERENCE FROM MAXIMUM HEIGHT: COMPLIES

RECOMMENDATION (IF APPLICABLE): EXHIBIT A

FROM: _____

EXHIBIT A



Select a Model		Min. W: 11	Max. W: 32	Min. U: 132
(Model 0201)		Min. H: 23	Max. H: 64	
Excelsior Double Hung				
Top Sash Width	24.5000	Eazel Size		
Top Sash Height	26.2500	Width:	27.76	
Bottom Sash Width	25.0000	Height:	53.625	
Bottom Sash Height	26.2500	Estimation: Select Extension		
Buildup Sash Height	22.8125	Opening: Standard		
Top Glass Height	21.9625	Type: Standard		
Bottom Glass Width	21.8125	Screen: Full		
Bottom Glass Height	24.0625	Glass: Double Strength (2 mm)		
Bottom Glass Height	24.0625	<input type="checkbox"/> AC Sash Lubricator		
Screen Width	24.0625			
Screen Height	20.7500			
Top Sash Weight (Plus 5 lb)	20.75			
Top Balance Size (C/F)	6580			
Top Balance Size (S/In)	21.75			
Bottom Sash Weight	16 lb			
Bottom Balance Size (C/F)	PLC			
Bottom Balance Size (S/In)	25-6R			
Gross Opening Width	21.3440			
Gross Opening Height	20.0625			
Gross Opening Area (sq. ft.)	3.2520			

* **TO BE CALCULATED AREA**

24 x 50 = 1200 ÷ 144 = 8.3 sq ft