



APPLICATION FOR APPEAL

RECEIVED
MAR 14 2013
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____) CK # 2202
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:	
Tuesday,	<u>3-19-13</u>
Time	<u>1:30 P.M</u>
Location of Hearing:	
<u>Room 330 City Hall/Courthouse</u>	

Address Being Appealed:

Number & Street: 1220 Rice St City: St. Paul State: MN Zip: 55117

Appellant/Applicant: Tin Cup Bar Email TinCup1220@yahoo.com

Phone Numbers: Business 487-7967 Residence _____ Cell _____

Signature: Midget Bailey Date: 3/13/13

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

they are saying I have to
much square footage for
49 people in the basement



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

February 15, 2013

TIN CUPS
1220 RICE ST
ST PAUL MN 55117

RE: RE-INSPECTION FIRE CERTIFICATE OF OCCUPANCY WITH DEFICIENCIES
1220 RICE ST
Ref. # 13517

Dear Property Representative:

Your building was re-inspected for the Fire Certificate of Occupancy on January 4, 2013. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected immediately.

A re-inspection will be made on or after March 15, 2013.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

DEFICIENCY LIST

1. LOWER LEVEL BACK EXIT - MSFC 1005.2 - Provide an approved additional means of egress due to an inadequate number of exits.-Refer to letter dated November 16, 2012.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at kris.skow-fiske@ci.stpaul.mn.us or call me at 651-266-8949 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,
Kris Skow-Fiske
Fire Inspector



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

November 16, 2012

Tin Cups
1220 Rice St.
St Paul MN 55104

RE: Lower Level Occupant Load

There are a couple of options for the Tin Cup lower level occupant load;

1. Renew and comply with the agreement to establish and limit the lower level occupant load at maximum of 49 persons. Properly identify the approved front exit and remove the exit sign from the rear door. Arrange the room to limit the additional useable square footage of the floor area. Establish approved operational procedures that would ensure that Tin Cup staff manage and maintain the agreed maximum of 49 persons.
2. Establish the approved occupant load at the calculated maximum of 60 persons. Provide an approved automatic fire sprinkler system throughout the lower level. Improve the path of travel to the existing rear door. Including exit and direction to exit signs, doors swing in the direction of exit travel, proper locks, and latches and exit hardware,
3. Provide an additional approved means of egress and exit at a location other than routing exit travel thru the kitchen and storage areas.
4. Appeal ordering to Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102. Phone: (651) 266-8688.

Sincerely,

Kris Skow-Fiske
Fire Inspector