

RECEIVED

OCT 25 2010



APPLICATION FOR APPEAL

Saint Paul City Clerk
15 W. Kellogg Blvd., 310 City Hall
Saint Paul, Minnesota 55102
Telephone: (651) 266-8688

1. Address of Property being Appealed: <i>1153 Hawthorne Ave E.</i>	2. Number of Dwelling Units: <i>3</i>	3. Date of Letter Appealed: <i>10/25/10</i>
--	--	--

4. Name of Owner: *PAT + SUE CONNOLLY*
 Address: *1153 Hawthorne Ave E.* City: *St. Paul* State: *MN* Zip: *55106*
 Phone Numbers: Business _____ Residence *651-778-8669* Cellular _____
 Signature: _____

5. Appellant / Applicant (if other than owner): *Pella Windows + Doors - ATTN BRIAN BENNETT*
 Address: *15300 25th Ave N* City: *Plymouth* State: *MN* Zip: *55447*
 Phone Numbers: Business *763-745-1400* Residence _____ Cellular *612-840-7986*
 Signature: *Brian Bennett*

6 State specifically what is being appealed and why (Use an attachment if necessary):

APPEALING MINIMUM EGRESS CLEAR OPENING HEIGHT FOR RESIDENCE'S BEDROOMS. THERE ARE 7 UPPER LEVEL DOUBLE HUNG WINDOWS THAT ARE UPSTAIRS, BUT ONLY 3 WE ARE APPEALING.

PELLA WINDOWS + CUSTOMER WANT THESE DECIDED PRIOR TO CUSTOMER CLOSING ANYTHING AND MOVING FORWARD W/ PROJECT

NOTE: A \$25.00 filing fee made payable to the City of Saint Paul must accompany this application as a necessary condition for filing. You must attach a copy of the original orders and any other correspondence relative to this appeal. Any person unsatisfied by the final decision of the City Council may obtain judicial review by timely filing of an action as provided by law in District Court.

For Office Use Only

Date Received: <i>10/25/10</i>	Fee Received: <i>25</i>	Receipt Number:	Date of Hearing: <i>11/2/10 at 1:30</i>
-----------------------------------	----------------------------	-----------------	--



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 25, 2010

APPEAL PROPERTY ADDRESS: 1153 HAWTHORNE AVE E
APPLICANT NAME: PELLA WINDOWS & DOORS TWIN CITIES INC
PHONE NUMBER: 651-266-9071
PERMIT NUMBER: 10 914006
TYPE OF WINDOW Double Hung
NUMBER OF WINDOWS 3

Total Glazed Area	5 sq. ft.	Difference from Required Area	NA
Width of Opening	20"	Difference from Required Opening	NA
Height of Opening	21.25"	Difference from Required Opening	-2.75"
Height of Opening to Finished Floor	NA	Difference from Maximum Height	NA

COMMENTS:

Reviewed by: B.H.