



CITY OF SAINT PAUL  
*Christopher B. Coleman, Mayor*

375 Jackson Street, Suite 220  
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989  
Facsimile: 651-266-8951  
Web: [www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)

April 15, 2014

BEE VUE  
21301 FURMAN ST NE  
WYOMING MN 55092-9626

**NOTICE OF CONDEMNATION  
UNFIT FOR HUMAN HABITATION  
ORDER TO VACATE**

RE: 606 BUSH AVE  
Ref. # 101405

Dear Property Representative:

Your building was inspected on April 15, 2014.

The building was found to be unsafe, unfit for human habitation, a public nuisance, a hazard to the public welfare or otherwise dangerous to human life. A Condemnation Placard has been posted on the building.

The following deficiency list must be completed or the building vacated by the re-inspection date.

**CONDEMNATION OF THE BUILDING REVOKES THE CERTIFICATE OF OCCUPANCY.**

Failure to complete the corrections may result in a criminal citation. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy.

**DEFICIENCY LIST**

1. Bathroom - SPLC 34.10 (4), 34.33 (3) - Provide a bathroom floor impervious to water.  
-There are numerous tiles missing in the bathroom floor.

2. Dogs not licensed - SPLC 200.02 (a) No person shall own, harbor, keep or maintain in the City and dog over three months of age without a license. Provide written documentation of current license to the Fire Inspector. To obtain a dog license, contact DSI at 651-266-8989
3. Stairs to the second floor - MSFC 104.9, 1005.3.2.2 - Remove the storage under the stairs or provide and maintain 1 hour fire resistive construction on the storage side of the stairs.
4. Throughout - MSFC 1028.3 - Remove the materials that cause an exit obstruction. Maintain a clear and unobstructed exitway.  
-The doors and windows had piles of clothes and garbage in front and behind them
5. Throughout - MN Stat 299F.18 - Immediately remove and discontinue excessive accumulation of combustible materials.  
-Reduce clutter by 75% throughout.
6. Throughout - SPLC 34.10 (6), 34.33 (5) - Exterminate and control insects, rodents or other pests. Provide documentation of extermination.
7. Throughout - SPLC 34.10 (5), 34.33 (4), 34.16 - Provide and maintain interior in a clean and sanitary condition.  
-The pets were defecating and urinating throughout the house.
8. Throughout - SPLC 34.08 (3) - Provide and maintain suitable ground cover on all exterior areas to control erosion.
9. Water Heater - UMC 1346.703 - Provide 30 inches clearance around all mechanical equipment.
10. SPLC 34.08 (1), 34.31 (1) - All exterior property areas shall be maintained free from any accumulation of refuse, garbage or feces.  
-There is garbage, furniture, and feces throughout the front and back yard.
11. **SPLC 34.23, MSFC 110.1 - This occupancy is condemned as unfit for human habitation. This occupancy must not be used until re-inspected and approved by this office.**  
  
**-The interior of this property is unlivable due to sanitation issues.**
12. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
13. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at: [brian.tonnancour@ci.stpaul.mn.us](mailto:brian.tonnancour@ci.stpaul.mn.us) or call me at 651-266-8955 between 7:30 - 9:00 a.m. Please help make Saint Paul a safer place in which to live and work.

Sincerely,

Brian Tonnancour  
Fire Inspector  
Ref. # 101405

cc: Housing Resource Center  
Force Unit