



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

April 12, 2011

Dennis Potapenko
Northland Home Exteriors
308 15th Street SW Suite 202
Forest Lake MN 55025

VIA EMAIL: dennis@northlandhome.net

Re: Appeal for property at 467 Arlington Avenue East
File ID #: ALH 11-463

Dear Mr. Potapenko:

This is to confirm that the Legislative Hearing Officer reviewed the above-referenced appeal and recommended granting a 7.5-inch variance on the openable height of three double hung replacement egress bedroom windows measuring 16.5 inches high by 35 inches wide.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang
Legislative Hearing Coordinator

cc: Fire Supervisors (email)
Pat Fish (email)
Jim Bloom (email)
Stephen Ubl (email)
File