

Saint Paul - Ramsey County Department of Public Health
Environmental Health Section
2785 White Bear Avenue North Suite 350
Maplewood, MN 55109-1320
FAX: (651) 266-1177

RECEIVED Date: 5-24-11

MAY 18 2011

CITY CLERK FAX#: 6-8574

FACSIMILE TRANSMISSION

Cover Sheet and Transmittal Form

| | |
|-----------|--|
| To: | <u>Mai Yang, Paralegal</u> |
| Location: | <u>Legislative Hearing Office</u> <u>City of St. Paul</u> |
| Sender: | <u>Daniel Schmidt / Tim Yannarelli</u> <u>St. Paul - Ramsey Cty. Dept. of Public Health</u> |

This transmission consists of _____ pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1143 (DANIEL SCHMIDT)

Message:

| |
|---|
| <p><u>Request for Egress Window Non-Compliance Determination</u></p> <p><u>Attachments: Egress Window Non-Compliance Determination Form</u></p> |
|---|

CONFIDENTIALITY NOTICE

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 5-19-11

APPEAL PROPERTY ADDRESS: 453 ST. CLAIR

APPLICANT NAME: PUBLIC HEALTH (DANIEL) PHONE NUMBER: 651-266-1143

PERMIT NUMBER: _____

TYPE OF WINDOW: DH (DOUBLE HUNG)

NUMBER OF WINDOWS: 3

TOTAL GLAZED AREA: 7.7 sq ft

DIFFERENCE FROM REQUIRED AREA: COMPLIES

WIDTH OF OPENING: 21.3'

DIFFERENCE FROM REQUIRED OPENING: COMPLIES

HEIGHT OF OPENING: 20.0"


DIFFERENCE FROM REQUIRED OPENING: 4"

HEIGHT OF OPENING TO FINISHED FLOOR: 48"

DIFFERENCE FROM MAXIMUM HEIGHT: COMPLIES

RECOMMENDATION (IF APPLICABLE): _____

FROM: _____



Select a Model

| | | |
|------------------------------|---------|--------|
| (Model 0201) | | 0201 ▼ |
| Excalibur Double Hung | | |
| Top Sash Width | 22.5000 | |
| Top Sash Height | 25.2500 | |
| Bottom Sash Width | 23.5000 | |
| Bottom Sash Height | 26.2500 | |
| Top Glass Width | 20.8125 | |
| Top Glass Height | 23.5625 | |
| Bottom Glass Width | 21.8125 | |
| Bottom Glass Height | 24.5625 | |
| Screen Width | 22.0625 | |
| Screen Height | 50.7300 | |
| Top Sash Weight (Plus 6 lb) | 19 lb | |
| Top Balance Size (C.F) | 55RD | |
| Top Balance Size (Spiral) | 21-7R | |
| Bottom Sash Weight | 16 lb | |
| Bottom Balance Size (C.F) | 8LG | |
| Bottom Balance Size (Spiral) | 25-5R | |
| Egress Opening Width | 21.3440 | |
| Egress Opening Height | 20.0825 | |
| Egress Opening Area (sq.ft.) | 2.9740 | |

*

? TOTAL GLAZED AREA

→

| | | |
|------------|--------------------------|-----------------------------|
| Min. W: 11 | Max W: 52 | |
| Min. H: 20 | Max H: 84 | Max UI: 132 |
| Exact Size | | |
| Width: | 25.75 | 25.75 |
| Height: | 53.625 | 53.625 |
| Extrusion: | Select Extrusion ▼ | << For Arch-Top Models Only |
| Opening: | Exact Size ▼ | |
| Type: | Standard ▼ | |
| Screen: | Full ▼ | |
| Glass: | Double Strength (3 mm) ▼ | |

AC Sash Calculator

$22 \times 50.7 = 1,115 \div 144 = 7.7 \text{ sqft}$