



**CITY OF SAINT PAUL**  
OFFICE OF THE CITY COUNCIL  
310 CITY HALL  
15 WEST KELLOGG BOULEVARD  
SAINT PAUL, MN 55102-1615  
EMAIL: [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us)  
PHONE: (651) 266-8560 FAX: (651) 266-8574

February 17, 2011

Joanne  
Window Concepts Of Minnesota Inc  
990 Lone Oak Road Ste 114  
Eagan MN 55121

VIA EMAIL: [jseib@windowconceptsmn.com](mailto:jseib@windowconceptsmn.com)

Re: Appeal for property at 1308 Marion Street  
File ID: ALH 11-239

Dear Joanne:

This is to confirm that on February 8, 2011, the Legislative Hearing Officer, recommended granting a 6.5-inch variance on the openable height of one double hung replacement egress bedroom window which measured at 17.5 inches high by 25 inches wide.

If you have further questions, please contact me at 651-266-8563.

Sincerely,

Mai Vang  
Legislative Hearing Coordinator

c: Fire Supervisors (email)  
Pat Fish (email)  
Jim Bloom (email)  
Stephen Ubl (email)  
Eugene Neppi, 1308 Marion St, Saint Paul, MN 55117  
File

