

RECEIVED

SEP 27 2010

CITY CLERK



APPLICATION FOR APPEAL

Saint Paul City Clerk
15 W. Kellogg Blvd., 310 City Hall
Saint Paul, Minnesota 55102
Telephone: (651) 266-8688

1. Address of Property being Appealed: <u>2244 Dellridge Ave</u>	2. Number of Dwelling Units: <u>Single Family</u>	3. Date of Letter Appealed: <u>09-24-10</u>
---	--	--

4. Name of Owner: Connie & Carl Zabel
 Address: 2244 Dellridge Ave City: St. Paul State: MN Zip: 55116
 Phone Numbers: Business _____ Residence 651-493-2025 Cellular _____
 Signature: _____

5. Appellant / Applicant (if other than owner): Renewal by Andersen
 Address: 1920 W CH Rd C City: Roseville State: MN Zip: 55113
 Phone Numbers: Business 651-264-4088 Residence _____ Cellular _____
 Signature: [Signature] Bryan Horton

6 State specifically what is being appealed and why (Use an attachment if necessary):
We are appealing a Sliding replacement window that will not comply w/ Egress policy. Current window will be short in operable width by 4 3/8". We are changing the original style to allow for greater operable height. Due to the width of this opening we're unable to put in a single casement. The job is small and by altering the opening to be compliant it would add over \$1,000 to the job cost. Since siding also makes alteration hard w/o finding a separate contractor. Please Approve.

NOTE: A \$25.00 filing fee made payable to the City of Saint Paul must accompany this application as a necessary condition for filing. You must attach a copy of the original orders and any other correspondence relative to this appeal. Any person unsatisfied by the final decision of the City Council may obtain judicial review by timely filing of an action as provided by law in District Court.

For Office Use Only

Date Received: <u>9/27/10</u>	Fee Received: <u>25pd</u>	Receipt Number:	Date of Hearing: <u>Oct 5 @ 1:30</u>
----------------------------------	------------------------------	-----------------	---

Revised 4/25/2007



**CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM**

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: September 24, 2010

APPEAL PROPERTY ADDRESS: 2244 DELLRIDGE AVE
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-266-9071
PERMIT NUMBER: 10 902220
TYPE OF WINDOW: Gliding Window
NUMBER OF WINDOWS: 1

Total Glazed Area	10.3 sq. ft.	Difference from Required Area	+ 5.3 sq. ft.
Width of Opening	15 5/8 "	Difference from Required Opening	- 4 3/8 "
Height of Opening	33 3/4 "	Difference from Required Opening	+ 9 3/4 "
Height of Opening to Finished Floor	NA	Difference from Maximum Height	NA

COMMENTS: Do to information provided above recommend approval.

Reviewed by: B.H.