



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

December 2, 2010

Susan Sweeney
1698 E. Sims Ave
St. Paul, MN 55106

Re: Appeal for property at 128 Case Avenue East
File ID: ALH 10-431

Dear Ms. Sweeney:

This is to confirm that on November 30, 2010 at the Property Code Hearing, Marcia Moermond, Legislative Hearing Officer recommended denying the appeal on the sill height requirement and granting an extension to March 1, 2011. You must install permanent affixed one steps or at least two steps full width (7 $\frac{3}{4}$) and 11 inches in depth below the window designated for egress. The remaining items on the list are also granted until March 1, 2011.

If you have any questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang
Legislative Hearing Coordinator

cc: Fire Supervisors (email)
Pat Fish (email)
File

