



# APPLICATION FOR APPEAL

RECEIVED  
MAY 11 2012  
CITY CLERK

**Saint Paul City Clerk**  
310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☐ \$25 filing fee payable to the City of Saint Paul  
(if cash: receipt number \_\_\_\_\_)
- ☒ Copy of the City-issued orders or letter which  
are being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed
- ☒ Walk-In OR ☐ Mail-In

**YOUR HEARING Date and Time:**

Tuesday, May 22, 2012

Time 1:30 p.m.

**Location of Hearing:**

Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 2101 BURNS AVE City: ST PAUL State: MN Zip: 55106

Appellant/Applicant: J.D. NELSON CONSTRUCTION Email: JDNELSONCONSTRUCTION@HOTMAIL.COM

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

Signature: [Signature] Date: \_\_\_\_\_

Name of Owner (if other than Appellant): STEVE HANSON

Address (if not Appellant's): \_\_\_\_\_

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

## What Is Being Appealed and Why?

*Attachments Are Acceptable*

- ☐ Vacate Order/Condemnation/  
Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List
- ☐ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☒ Other



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

## EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: May 11, 2012

APPEAL PROPERTY ADDRESS: 2101 BURNS AVE

APPLICANT NAME: J D NELSON CONSTRUCTION LLC

PHONE NUMBER: 651-208-2716

PERMIT NUMBER: 12 048515

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 2

|                                                                                       |      |                                         |      |
|---------------------------------------------------------------------------------------|------|-----------------------------------------|------|
| <b>Total Glazed Area</b><br>Minimum 5 Square Feet                                     | 10.2 | <b>Difference from Required Area</b>    | +5.2 |
| <b>Width of Opening</b><br>Minimum 20 Inches                                          | 36"  | <b>Difference from Required Opening</b> | +16" |
| <b>Height of Opening</b><br>Minimum 24 Inches                                         | 14"  | <b>Difference from Required Opening</b> | -10" |
| <b>Height of Opening to Finished Floor</b><br>Maximum 48 Inches for Existing Openings | <48" | <b>Difference from Maximum Height</b>   | ok   |

COMMENTS:

Reviewed by: DD 5-11-12