



APPLICATION FOR APPEAL

JAN 04 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:	
Tuesday,	<u>1-11-2011</u>
Time	<u>1:30</u>
Location of Hearing:	
<u>Room 330 City Hall/Courthouse</u>	

Address Being Appealed:

Number & Street: 1811 Eleanor Ave City: St. Paul State: MN Zip: 55116

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: 12/20/10

Name of Owner (if other than Appellant): Cindy & Steve McComas

Address (if not Appellant's): 1811 Eleanor Ave

Phone Numbers: Business 612-624-4678 Residence 651-699-0125 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 1 replacement double hung that is not compliant w/ Egress Policies. Operable height is 18" and operable width is 43". We believe there is enough excess operable width to make up for short fall in operable height. Please Approve.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: December 21, 2010

APPEAL PROPERTY ADDRESS: 1811 ELEANOR AVE

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-266-9071

PERMIT NUMBER: 10 936625

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 1

Total Glazed Area	14.9	Difference from Required Area	+9.9
Width of Opening	43	Difference from Required Opening	+23
Height of Opening	18	Difference from Required Opening	-6
Height of Opening to Finished Floor	36	Difference from Maximum Height	ok

COMMENTS: With the information provided above approval is recommended. 12-21-10 rr

Reviewed by: Rehn